

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

6521877 (S/N 1266) Component Compressor

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	/ ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014705	KCPA016480	KCP015263
Sample Date		Client Info		14 May 2024	19 Apr 2024	13 Mar 2024
Machine Age	hrs	Client Info		13055	12978	12550
Oil Age	hrs	Client Info		1178	901	473
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	3	2	3
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	1	<1	<1
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	<1	45	116
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	18	39	56
Calcium	ppm	ASTM D5185m	2	0	0	3
Phosphorus	ppm	ASTM D5185m		249	268	244
Zinc	ppm	ASTM D5185m		27	19	15
Sulfur	ppm	ASTM D5185m		3005	4156	3202
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		11	15	22
Potassium	ppm	ASTM D5185m	>20	2	2	4
Water	%	ASTM D6304	>0.05	0.013	0.017	0.013
ppm Water	ppm	ASTM D6304	>500	131	178	137
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2100	82536	1731
Particles >6µm		ASTM D7647	>1300	575	A 29225	595
Particles >14µm		ASTM D7647	>80	24	1 174	71
Particles >21µm		ASTM D7647	>20	4	🔺 164	21
Particles >38µm		ASTM D7647	>4	0	2	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	<u> </u>	18/16/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.45	0.48	0.40


Contact/Location: Service Manager - DOMSANVA Page 1 of 2





OIL ANALYSIS REPORT
















	0000.00	1.00.00				
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	46.1	48.9	46.2
SAMPLE IMAGES		method	limit/base	current	historv1	historv2

Color



Bottom



Unique Number : 11032657 Certificate 12367

- Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.
- * Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: DOMSANVA [WUSCAR] 06181331 (Generated: 05/20/2024 10:12:16) Rev: 1

Contact/Location: Service Manager - DOMSANVA

T:

F:

Contact: Service Manager