


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

MIX MIXER

Component

Component **Gearbox**

{not provided} (--- LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jun 202	3 Dec2023	Mar2024 M	ay2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP234608	USP213440	USP234602
Sample Date		Client Info		15 May 2024	03 Mar 2024	04 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	106	121	26
Chromium	ppm	ASTM D5185m	>15	8	5	<1
Nickel	ppm	ASTM D5185m	>15	2	2	0
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m		<1	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	1	<1	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	6
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		1	3	<1
Magnesium	ppm	ASTM D5185m		0	7	0
Calcium	ppm	ASTM D5185m		46	2009	796
Phosphorus	ppm	ASTM D5185m		553	681	563
Zinc	ppm	ASTM D5185m		10	21	0
Sulfur	ppm	ASTM D5185m		1379	894	1242
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	2	6	5
Sodium	ppm	ASTM D5185m		5	2	2
Potassium	ppm	ASTM D5185m	>20	<1	0	<1
Water	%	ASTM D6304	>0.2	0.006	0.014	0.008
ppm Water	ppm	ASTM D6304	>2000	65	147	86
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	146039	<u>▲</u> 175657	<u></u> 113362
Particles >6µm		ASTM D7647	>2500	4 34501	▲ 60923	△ 10232
Particles >14µm		ASTM D7647	>640	181	358	41
Particles >21µm		ASTM D7647	>160	22	73	8
Particles >38µm		ASTM D7647	>40	1	4	1
Particles >71µm		ASTM D7647	>10	1	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16	<u>4</u> 24/22/15	<u>\$\lambda\$\$ 25/23/16</u>	2 4/21/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.51	0.44	0.372



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No. Lab Number

: USP234608 : 06181336 Unique Number : 11032662

Received : 16 May 2024 Tested : 17 May 2024 Diagnosed

: 20 May 2024 - Angela Borella Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: RON MOGENSEN ronnie.mogensen@kraftheinz.com

Report Id: KRAFORFL [WUSCAR] 06181336 (Generated: 05/20/2024 10:25:56) Rev: 1

Contact/Location: RON MOGENSEN - KRAFORFL

5521 DIVISION DR

FORT MYERS, FL

US 33905

T:

F: