

OIL ANALYSIS REPORT

Sample Rating Trend

VISCOSITY

Machine Id **CUP DECK - C TANK XFER (S/N 10241L74415981)** Pump

Fluid COMP OIL (POE) ISO 220 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The oil viscosity is lower than normal. The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		USP0011830		
Sample Date		Client Info		15 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	49		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m	>5	0		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>3	<1		
Aluminum	ppm	ASTM D5185m	>7	1		
Lead	ppm	ASTM D5185m	>12	0		
Copper	ppm	ASTM D5185m	>30	<1		
Tin	ppm	ASTM D5185m	>9	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0		
Barium	ppm	ASTM D5185m	5	0		
Molybdenum	ppm	ASTM D5185m	5	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	5	0		
Calcium	ppm	ASTM D5185m	5	2		
Phosphorus	ppm	ASTM D5185m	400	467		
Zinc	ppm	ASTM D5185m	5	21		
Sulfur	ppm	ASTM D5185m	100	762		
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	17		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	1		
Water	%	ASTM D6304	>.1	0.010		
ppm Water	ppm	ASTM D6304	>1000	105		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	6 57872		
Particles >6µm		ASTM D7647	>2500	<u> </u>		
Particles >14µm		ASTM D7647	>640	131		
Particles >21µm		ASTM D7647	>160	19		
Particles >38µm		ASTM D7647	>40	0		
Particles >71µm		ASTM D7647	>10	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/16	A 23/20/14		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.40	0.49		



OIL ANALYSIS REPORT

limit/base

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

limit/base

limit/base

491.52

122,88

30.72

7.68

1.920

480

120

31

(^{0.50} (⁰/HOX) 0.40

Ē 0.30

e 0.20

Acid

0.10

0.00

Mav1

Bas

(per 1 ml) May15/24

es les

Aav15/7

May15/24

: 16 May 2024

: 23 May 2024

>.1

220

current

NONE

NONE

NONE

NONE

LIGHT

NONE

NORML

NORML

current

current

Particle Count

Acid Number

NEG

NEG

188.4

history1

history

history1

no image

no image

history2

history

history2


no image

no imade

4406

:1999 Cle

14



21µ

Contact/Location: Paul Jones - KRAJACHEI

Page 2 of 2