Sullivan Palatek

OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Area
QUANDRA COOLANT
Machine Id
SULLIVAN PALATEK 1308120007 - KERFORD LIMESTONE UNIT 4
Component
Compressor

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**UCS06181446**	UCS06131458	UCS03851251
Sample Date		Client Info		**26 Apr 2024**	08 Mar 2024	18 Sep 2015
Machine Age	hrs	Client Info		**65692**	64681	12529
Oil Age	hrs	Client Info		**0**	2100	998
Oil Changed		Client Info		**N/A**	Not Changd	Not Changd
Sample Status				**NORMAL**	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**2**	1	0
Chromium	ppm	ASTM D5185m	>10	**<1**	<1	0
Nickel	ppm	ASTM D5185m		**<1**	<1	0
Titanium	ppm	ASTM D5185m		**<1**	<1	0
Silver	ppm	ASTM D5185m		**<1**	<1	0
Aluminum	ppm	ASTM D5185m	>25	**1**	2	0
Lead	ppm	ASTM D5185m	>25	**<1**	<1	0
Copper	ppm	ASTM D5185m	>50	**2**	1	0
Tin	ppm	ASTM D5185m	>15	**<1**	<1	2
Antimony	ppm	ASTM D5185m		**---**	---	0
Vanadium	ppm	ASTM D5185m		**<1**	<1	0
Cadmium	ppm	ASTM D5185m		**<1**	<1	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**<1**	0	0
Barium	ppm	ASTM D5185m		**582**	667	0
Molybdenum	ppm	ASTM D5185m		**<1**	<1	0
Manganese	ppm	ASTM D5185m		**<1**	<1	0
Magnesium	ppm	ASTM D5185m		**3**	<1	0
Calcium	ppm	ASTM D5185m		**15**	7	0
Phosphorus	ppm	ASTM D5185m		**109**	93	716
Zinc	ppm	ASTM D5185m		**8**	0	0
Sulfur	ppm	ASTM D5185m		**850**	409	944

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**4**	1	0
Sodium	ppm	ASTM D5185m		**26**	13	0
Potassium	ppm	ASTM D5185m	>20	**3**	2	2

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.34**	0.14	0.112

Sullivan Palatek

OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**LIGHT**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	MODER	HEAVY
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		**52.1**	52.6	42.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					*no image*
Bottom					*no image*

GRAPHS









Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : UCS06181446
Lab Number : 06181446
Unique Number : 11032772
Test Package : IND 2

Received : 16 May 2024
Tested : 17 May 2024
Diagnosed : 20 May 2024 - Sean Felton

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

RASMUSSEN AIR & GAS ENERGY - RAGE
655 240TH STREET
WATERLOO, NE
US 68069
Contact: CHASE SVOBODA
chase.svoboda@rage-energy.com
T: (402)614-9926
F: