




# OIL ANALYSIS REPORT



Machine Id  
**JENBACHER GM03 (S/N 1251395)**  
 Component  
**Biogas Engine**  
 Fluid  
**MAHLER Q8 Mahler G8 SAE 40 (--- GAL)**

## Sample Rating Trend



**NORMAL**



### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SAMPLE INFORMATION |             | method      | limit/base | current            | history1    | history2    |
|--------------------|-------------|-------------|------------|--------------------|-------------|-------------|
| Sample Number      | Client Info |             |            | <b>WC0944694</b>   | WC0880316   | WC0880346   |
| Sample Date        | Client Info |             |            | <b>15 May 2024</b> | 12 Mar 2024 | 26 Feb 2024 |
| Machine Age        | hrs         | Client Info |            | <b>24740</b>       | 23222       | 22897       |
| Oil Age            | hrs         | Client Info |            | <b>448</b>         | 2994        | 2666        |
| Oil Changed        | Client Info |             |            | <b>N/A</b>         | N/A         | N/A         |
| Sample Status      |             |             |            | <b>NORMAL</b>      | NORMAL      | NORMAL      |

| CONTAMINATION |           | method | limit/base | current        | history1 | history2 |
|---------------|-----------|--------|------------|----------------|----------|----------|
| Fuel          | WC Method | >4.0   |            | <b>&lt;1.0</b> | <1.0     | <1.0     |
| Water         | WC Method | >.2    |            | <b>NEG</b>     | NEG      | NEG      |
| Glycol        | WC Method |        |            | <b>NEG</b>     | NEG      | NEG      |

| WEAR METALS |     | method      | limit/base | current      | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron        | ppm | ASTM D5185m | >20        | <b>3</b>     | 5        | <1       |
| Chromium    | ppm | ASTM D5185m | >5         | <b>&lt;1</b> | <1       | <1       |
| Nickel      | ppm | ASTM D5185m | >2         | <b>&lt;1</b> | 0        | 0        |
| Titanium    | ppm | ASTM D5185m |            | <b>&lt;1</b> | 0        | 0        |
| Silver      | ppm | ASTM D5185m | >5         | <b>&lt;1</b> | 0        | 0        |
| Aluminum    | ppm | ASTM D5185m | >15        | <b>4</b>     | 3        | 2        |
| Lead        | ppm | ASTM D5185m | >20        | <b>&lt;1</b> | <1       | <1       |
| Copper      | ppm | ASTM D5185m | >15        | <b>1</b>     | <1       | <1       |
| Tin         | ppm | ASTM D5185m | >5         | <b>&lt;1</b> | 0        | <1       |
| Vanadium    | ppm | ASTM D5185m |            | <b>&lt;1</b> | 0        | 0        |
| Cadmium     | ppm | ASTM D5185m |            | <b>&lt;1</b> | 0        | 0        |

| ADDITIVES  |     | method      | limit/base | current      | history1 | history2 |
|------------|-----|-------------|------------|--------------|----------|----------|
| Boron      | ppm | ASTM D5185m |            | <b>2</b>     | 2        | <1       |
| Barium     | ppm | ASTM D5185m |            | <b>&lt;1</b> | 0        | 0        |
| Molybdenum | ppm | ASTM D5185m |            | <b>3</b>     | 3        | <1       |
| Manganese  | ppm | ASTM D5185m |            | <b>&lt;1</b> | 0        | <1       |
| Magnesium  | ppm | ASTM D5185m |            | <b>20</b>    | 31       | 12       |
| Calcium    | ppm | ASTM D5185m |            | <b>3519</b>  | 2492     | 2246     |
| Phosphorus | ppm | ASTM D5185m |            | <b>692</b>   | 511      | 426      |
| Zinc       | ppm | ASTM D5185m |            | <b>882</b>   | 555      | 504      |
| Sulfur     | ppm | ASTM D5185m |            | <b>3972</b>  | 2711     | 2302     |

| CONTAMINANTS |     | method      | limit/base | current  | history1 | history2 |
|--------------|-----|-------------|------------|----------|----------|----------|
| Silicon      | ppm | ASTM D5185m | >200       | <b>4</b> | 5        | 4        |
| Sodium       | ppm | ASTM D5185m | >20        | <b>3</b> | 0        | <1       |
| Potassium    | ppm | ASTM D5185m | >20        | <b>2</b> | 1        | 0        |


| INFRA-RED |          | method      | limit/base | current     | history1 | history2 |
|-----------|----------|-------------|------------|-------------|----------|----------|
| Soot %    | %        | *ASTM D7844 | >2         | <b>0</b>    | 0.1      | 0        |
| Nitration | Abs/cm   | *ASTM D7624 | >20        | <b>6.3</b>  | 9.4      | 9.0      |
| Sulfation | Abs/.1mm | *ASTM D7415 | >30        | <b>15.4</b> | 17.9     | 17.5     |

| FLUID DEGRADATION |          | method      | limit/base | current      | history1 | history2 |
|-------------------|----------|-------------|------------|--------------|----------|----------|
| Oxidation         | Abs/.1mm | *ASTM D7414 | >25        | <b>10.2</b>  | 15.2     | 14.7     |
| Acid Number (AN)  | mg KOH/g | ASTM D8045  |            | <b>1.363</b> | 1.53     | 0.66     |
| Base Number (BN)  | mg KOH/g | ASTM D2896  | 8.0        | <b>8.00</b>  | 6.05     | 6.01     |




# OIL ANALYSIS REPORT


FT-IR (Direct Trend)




Acid Number



Base Number











Viscosity @ 100°C



| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | NONE     |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Silt             | scalar | *Visual    | NONE    | NONE     | NONE     |
| Debris           | scalar | *Visual    | NONE    | NONE     | NONE     |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | NONE     |
| Appearance       | scalar | *Visual    | NORML   | NORML    | NORML    |
| Odor             | scalar | *Visual    | NORML   | NORML    | NORML    |
| Emulsified Water | scalar | *Visual    | >.2     | NEG      | NEG      |
| Free Water       | scalar | *Visual    |         | NEG      | NEG      |

| FLUID PROPERTIES | method | limit/base | current | history1    | history2 |
|------------------|--------|------------|---------|-------------|----------|
| Visc @ 100°C     | cSt    | ASTM D445  | 13.2    | <b>13.4</b> | 14.2     |

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0944694  
 Lab Number : 06181524  
 Unique Number : 11032850  
 Test Package : MOB 2

Received : 16 May 2024  
 Tested : 28 May 2024  
 Diagnosed : 28 May 2024 - Doug Bogart

**ASB MAS GA LFG PLANT COGEN**  
 3791 BROWNS MILL RD SE  
 ATLANTA, GA  
 US 30354  
 Contact: DEREK PAGE  
 derek.page@cubedistrictenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)