


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



BEKEVAR [46004111] D622330 (S/N CM0071)

Wind Turbine Gearbox

SHELL OMALA S5 WIND 320 (--- LTR)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Dec2023	AprŽ024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX014229	NX014239	
Sample Date		Client Info		26 Apr 2024	20 Dec 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Not Changd	Not Changd	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		13	16	
Iron	ppm	ASTM D5185m	>200	<1	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>10	0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m		<1	0	
Lead	ppm	ASTM D5185m		0	0	
Copper	ppm	ASTM D5185m		<1	0	
Tin	ppm	ASTM D5185m		<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
	ррпп			ŭ		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m		0	0	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m		467	436	
Zinc	ppm	ASTM D5185m		0	4	
Sulfur	ppm	ASTM D5185m		3853	3422	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		2	<1	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	1	<1	
Water	%	ASTM D6304	>0.2	0.009	0.012	
ppm Water	ppm	ASTM D6304	>2000	93	127	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1339	4535	
Particles >6µm		ASTM D7647	>1300	348	1279	
Particles >14µm		ASTM D7647	>160	21	106	
Particles >21µm		ASTM D7647	>40	5	25	
Particles >38µm		ASTM D7647	>10	1	1	
Particles >71μm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>17/14	16/12	17/14	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number Unique Number : 11033192

: NX014229 : 06181866

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received **Tested** Diagnosed Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

: 16 May 2024 : 20 May 2024 : 20 May 2024 - Angela Borella

300 SOUTH WACKER DRIVE, SUITE 1500 CHICAGO, IL US 60606

Contact: KEVIN REGAN KRegan@nordex-online.com

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (312)386-7102 Contact/Location: KEVIN REGAN - NORDEX

T: