




# COOLANT REPORT

## Sample Rating Trend



**NORMAL**



Area

**Louisville**

Machine Id

**[Louisville] Coolant - Port Main Engine (Aftercooler)**

Component

**Coolant**

Fluid

**CATERPILLAR ELC (--- GAL)**

### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

#### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

#### Contaminants

There is no indication of any contamination in the coolant.

#### Coolant Condition

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0874766</b>	WC0804840	WC0859791
Sample Date	Client Info		<b>28 Apr 2024</b>	30 Jan 2024	08 Dec 2023
Machine Age	hrs	Client Info	<b>950</b>	39417	38606
Oil Age	hrs	Client Info	<b>950</b>	0	0
Oil Changed		Client Info	<b>N/A</b>	N/A	N/A
Sample Status			<b>NORMAL</b>	NORMAL	ABNORMAL

### PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Glycol Type	FT-IR		<b>---</b>	---	---
Specific Gravity	*ASTM D1298		<b>1.061</b>	1.052	1.055
pH	Scale 0-14	ASTM D1287	<b>8.39</b>	8.60	9.01
Nitrites	ppm	AP-053:2009	<b>824</b>	488	712
Reserve Alkalinity	Scale 0-20	*ASTM D1121	<b>---</b>	---	---
Percentage Glycol	%	ASTM D3321	<b>45.2</b>	38.4	40.6
Freezing Point	°F	ASTM D3321	<b>-24</b>	-9	-13
Total Dissolved Solids			<b>273.0</b>	243.0	242.0
Carboxylate			<b>fail</b>	fail	fail

### CORROSION INHIBITORS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D6130	0	<b>2</b>	<1	4
Phosphorus	ppm	ASTM D6130	0	<b>0</b>	<1	2
Boron	ppm	ASTM D6130	0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D6130	950	<b>667</b>	494	519

### CORROSION

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D6130	>15	<b>0</b>	8	8
Aluminum	ppm	ASTM D6130	>10	<b>0</b>	<1	<1
Copper	ppm	ASTM D6130	>10	<b>0</b>	<1	<1
Lead	ppm	ASTM D6130	>10	<b>0</b>	<1	<1
Tin	ppm	ASTM D6130	>10	<b>0</b>	0	1
Zinc	ppm	ASTM D6130		<b>0</b>	0	0

### CONTAMINANTS

	method	limit/base	current	history1	history2	
Chlorine	ppm	ASTM D6130		<b>9</b>	7	8

### CARRIER SALTS


	method	limit/base	current	history1	history2	
Sodium	ppm	ASTM D6130		<b>4032</b>	3171	3248
Potassium	ppm	ASTM D6130		<b>14</b>	8	5

### SCALE POTENTIAL

	method	limit/base	current	history1	history2	
Calcium	ppm	ASTM D6130		<b>6</b>	5	2
Magnesium	ppm	ASTM D6130		<b>2</b>	<1	1









# COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual		Red	Red	Red
Coolant Appearance	*Visual	Clear	normal	normal	▲ sediment
Color					no image
Bottom					no image

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0874766

Lab Number : 06181902

Unique Number : 11033228

Test Package : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP, KF )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 16 May 2024

Tested : 24 May 2024

Diagnosed : 24 May 2024 - Jonathan Hester

MARATHON PETROLEUM CO.

101 12TH ST

CATLETTSBURG, KY

US 41169

Contact: CORY GUMBERT

cagumbert@marathonpetroleum.com

T: (606)585-3950

F: x: