

OIL ANALYSIS REPORT



DIAGNOSIS

A Recommendation

We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		FCH0000052		
Sample Date		Client Info		13 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.01	NEG		
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>8	2		
Chromium	ppm	ASTM D5185m	>2	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m	>2	<1		
Aluminum	ppm	ASTM D5185m	>3	0		
_ead	ppm	ASTM D5185m	>2	<1		
Copper	ppm	ASTM D5185m	>8	<1		
Гin	ppm	ASTM D5185m	>4	0		
/anadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Vanganese	ppm	ASTM D5185m		<1		
Vagnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		292		
Zinc	ppm	ASTM D5185m		31		
Sulfur	ppm	ASTM D5185m		3008		
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	45781		
Particles >6µm		ASTM D7647	>2500	<u> </u>		
Particles >14µm		ASTM D7647	>320	99		
Particles >21µm		ASTM D7647	>80	15		
Particles >38µm		ASTM D7647	>20	2		
^o articles >71µm		ASTM D7647	>4	2		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	A 23/20/14		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37		
·12·27) Boy: 1					Submitto	d By: Wee David







PB 0.10

0.05 0.00

80

71

() 10°C ŝ


65


60 May13/24

Mav1

Viscosity @ 40°C

OIL ANALYSIS REPORT





Certificate 12367

Laboratory

Sample No.

Submitted By: Wes Davis Page 2 of 2