




OIL ANALYSIS REPORT

Sample Rating Trend



SEDIMENT



Area
ROTH ROCK [200005321]

Machine Id
06WEA81554

Component
Wind Turbine Gearbox

Fluid
CASTROL OPTIGEAR SYNTHETIC A ISO 320 (--- LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		NX016944	NX012208	NX012209
Sample Date	Client Info		25 Apr 2024	18 Oct 2023	24 Mar 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ATTENTION	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184	>80	22	18	13	
Iron	ppm	ASTM D5185m	>150	31	55	59
Chromium	ppm	ASTM D5185m	>5	<1	<1	<1
Nickel	ppm	ASTM D5185m	>10	0	0	<1
Titanium	ppm	ASTM D5185m	>10	<1	0	<1
Silver	ppm	ASTM D5185m		<1	0	0
Aluminum	ppm	ASTM D5185m	>10	4	6	<1
Lead	ppm	ASTM D5185m	>20	<1	0	0
Copper	ppm	ASTM D5185m	>50	<1	2	<1
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	9	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	1150	938	478	525
Manganese	ppm	ASTM D5185m		1	2	2
Magnesium	ppm	ASTM D5185m	1800	2001	1590	1618
Calcium	ppm	ASTM D5185m	20	28	12	12
Phosphorus	ppm	ASTM D5185m	1450	1413	1118	1155
Zinc	ppm	ASTM D5185m	1650	1576	1251	1288
Sulfur	ppm	ASTM D5185m	4900	7221	4854	5626

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	14	9	9
Sodium	ppm	ASTM D5185m	>20	6	25	24
Potassium	ppm	ASTM D5185m	>20	0	0	3
Water	%	ASTM D6304	>0.1	0.035	0.078	0.041
ppm Water	ppm	ASTM D6304	>1000	351	790	413.3

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		---	10698	---
Particles >6µm	ASTM D7647	>2500	---	1568	---
Particles >14µm	ASTM D7647	>320	---	88	---
Particles >21µm	ASTM D7647	>80	---	24	---
Particles >38µm	ASTM D7647	>20	---	0	---
Particles >71µm	ASTM D7647	>4	---	0	---
Oil Cleanliness	ISO 4406 (c)	>--/18/15	---	21/18/14	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	3.3	2.64	2.57	1.50




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ MODER	NONE	▲ HEAVY
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 305	340	319	318

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : NX016944 **Received** : 17 May 2024
Lab Number : **06182829** **Tested** : 29 May 2024
Unique Number : 11034155 **Diagnosed** : 29 May 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

NORDEX USA - ROTH ROCK
 300 SOUTH WACKER DRIVE, SUITE 1500
 CHICAGO, IL
 US 60606
 Contact: ADAY MAGEC
 aday.magec@gestampren.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (312)386-7102