




# OIL ANALYSIS REPORT

Sample Rating Trend



SEDIMENT



Area  
**ROTH ROCK [200005321]**  
 Machine Id  
**17WEA81561**  
 Component  
**Wind Turbine Gearbox**  
 Fluid  
**CASTROL OPTIGEAR SYNTHETIC A ISO 320 (--- LTR)**

## DIAGNOSIS

- Recommendation**  
We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.
- Wear**  
All component wear rates are normal.
- Contamination**  
There is a moderate amount of visible silt present in the sample.
- Fluid Condition**  
An additive depletion is indicated. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>NX016982</b>	NX012200	NX012199
Sample Date	Client Info	<b>16 Apr 2024</b>	11 Oct 2023	04 Apr 2023
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ATTENTION	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2		
PQ	ASTM D8184	>80	<b>20</b>	16	16	
Iron	ppm	ASTM D5185m	>150	<b>61</b>	50	57
Chromium	ppm	ASTM D5185m	>5	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	>10	<b>&lt;1</b>	0	<1
Silver	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>3</b>	7	<1
Lead	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185m	>50	<b>&lt;1</b>	2	<1
Tin	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m	0	<b>0</b>	11	0
Barium	ppm	ASTM D5185m	0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	1150	<b>568</b>	563	585
Manganese	ppm	ASTM D5185m		<b>1</b>	2	2
Magnesium	ppm	ASTM D5185m	1800	<b>1708</b>	1654	1657
Calcium	ppm	ASTM D5185m	20	<b>12</b>	23	16
Phosphorus	ppm	ASTM D5185m	1450	<b>1215</b>	1178	1204
Zinc	ppm	ASTM D5185m	1650	<b>1415</b>	1349	1350
Sulfur	ppm	ASTM D5185m	4900	<b>5986</b>	5198	5784

## CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>50	<b>10</b>	10	10
Sodium	ppm	ASTM D5185m	>20	<b>20</b>	20	21
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	2
Water	%	ASTM D6304	>0.1	<b>0.041</b>	0.071	0.059
ppm Water	ppm	ASTM D6304	>1000	<b>411</b>	714	593.2

## FLUID CLEANLINESS





method	limit/base	current	history1	history2	
Particles >4µm	ASTM D7647	---	1606	---	
Particles >6µm	ASTM D7647	>2500	161	---	
Particles >14µm	ASTM D7647	>320	9	---	
Particles >21µm	ASTM D7647	>80	1	---	
Particles >38µm	ASTM D7647	>20	0	---	
Particles >71µm	ASTM D7647	>4	0	---	
Oil Cleanliness	ISO 4406 (c)	>--/18/15	---	18/15/10	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2		
Acid Number (AN)	mg KOH/g	ASTM D8045	3.3	<b>1.76</b>	2.484	1.56




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ MODER	NONE	▲ HEAVY
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 305	326	323	323

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : NX016982

Lab Number : 06182840

Unique Number : 11034166

Test Package : IND 2 ( Additional Tests: KF, PQ, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 17 May 2024

Tested : 21 May 2024

Diagnosed : 21 May 2024 - Jonathan Hester

NORDEX USA - ROTH ROCK

300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL

US 60606

Contact: ADAY MAGEC

aday.magec@gestampren.com

T:

F: (312)386-7102