




PROBLEM SUMMARY

Sample Rating Trend






DEGRADATION



Machine Id
INGERSOLL RAND 2 (100HP) (S/N MOX1002479)
 Component
Air Compressor
 Fluid
USPI MAX FG AIR 46 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status	ASTM	Value	SEVERE	SEVERE	NORMAL
Particles >4µm	ASTM D7647	>10000	▲ 23720	---	1547
Particles >6µm	ASTM D7647	>2500	▲ 6122	---	140
Particles >14µm	ASTM D7647	>320	▲ 435	---	10
Particles >21µm	ASTM D7647	>80	▲ 118	---	6
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 22/20/16	---	18/14/10
Acid Number (AN)	mg KOH/g ASTM D8045	0.16	▲ 6.834	▲ 7.852	0.188
Visc @ 40°C	cSt ASTM D445	45.8	▲ 68.3	▲ 65.4	51.3

Customer Id: TYSNORTX
 Sample No.: USPM36170
 Lab Number: 06182867
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.
Flush System	---	---	?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

DEGRADATION



23 Jul 2023 Diag: Doug Bogart

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is above the recommended limit. The oil viscosity is higher than normal. Confirmed.

view report



NORMAL



10 Jun 2021 Diag: Doug Bogart

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Machine Id
INGERSOLL RAND 2 (100HP) (S/N MOX1002479)
 Component
Air Compressor
 Fluid
USPI MAX FG AIR 46 (--- GAL)

DIAGNOSIS

▲ Recommendation

Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.

▲ Fluid Condition

The AN level is above the recommended limit. The oil viscosity is higher than normal. Confirm oil type.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USPM36170	USPM27431	USP224228
Sample Date	Client Info		16 May 2024	23 Jul 2023	10 Jun 2021
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	SEVERE	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	11	7	<1
Chromium	ppm	ASTM D5185m >4	0	0	0
Nickel	ppm	ASTM D5185m >4	0	0	0
Titanium	ppm	ASTM D5185m	0	<1	0
Silver	ppm	ASTM D5185m	<1	0	0
Aluminum	ppm	ASTM D5185m >10	0	0	0
Lead	ppm	ASTM D5185m >20	0	0	0
Copper	ppm	ASTM D5185m >40	12	7	0
Tin	ppm	ASTM D5185m >5	0	0	0
Antimony	ppm	ASTM D5185m	---	---	0
Vanadium	ppm	ASTM D5185m	<1	<1	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<1	0	4
Barium	ppm	ASTM D5185m 0	0	0	714
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m	0	<1	0
Magnesium	ppm	ASTM D5185m 0	0	<1	<1
Calcium	ppm	ASTM D5185m 0	0	0	3
Phosphorus	ppm	ASTM D5185m 0	0	5	20
Zinc	ppm	ASTM D5185m 0	7	12	0
Sulfur	ppm	ASTM D5185m 0	0	0	45

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	<1	<1
Sodium	ppm	ASTM D5185m	7	5	23
Potassium	ppm	ASTM D5185m >20	<1	2	1
Water	%	ASTM D6304 >0.6	0.076	0.085	0.457
ppm Water	ppm	ASTM D6304 >6000	769	855.4	4574.3

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 23720	---	1547
Particles >6µm	ASTM D7647	>2500	▲ 6122	---	140
Particles >14µm	ASTM D7647	>320	▲ 435	---	10
Particles >21µm	ASTM D7647	>80	▲ 118	---	6
Particles >38µm	ASTM D7647	>20	5	---	0
Particles >71µm	ASTM D7647	>4	0	---	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 22/20/16	---	18/14/10

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.16	▲ 6.834	▲ 7.852	0.188




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45.8 ▲ 68.3	▲ 65.4	51.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM36170 **Received** : 17 May 2024
Lab Number : **06182867** **Tested** : 21 May 2024
Unique Number : 11034193 **Diagnosed** : 21 May 2024 - Jonathan Hester
Test Package : IND 2

TYSON-NORTH RICHLAND HILLS-USP
 6350 BLOWN CT
 NORTH RICHLAND HILLS, TX
 US 76180
 Contact: JOHN MORGAN

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (817)514-3519
 F: