


# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area  
**Marcus Hook/Cryogenic/Compressor**  
 Machine Id  
**CRYOGENIC COMPRESSOR 50-C-101D**  
 Component  
**Rotary Compressor**  
 Fluid  
**LUBSOIL SYNTHETIC COMPRESSOR 100 (220 GAL)**

**DIAGNOSIS**

**Recommendation**  
 Resample at the next service interval to monitor. We were unable to perform a particle count due to insufficient sample. ( Customer Sample Comment: Lubsoil Syn Comp 100 )

**Wear**  
 All component wear rates are normal.

**Contamination**  
 The water content is negligible. There is no indication of any contamination in the oil.

**Fluid Condition**  
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>TO90002165</b>	TO60001807	TO60001820
Sample Date	Client Info			<b>09 May 2024</b>	09 May 2024	05 Nov 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	ABNORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>70	<b>10</b>	10	4
Chromium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m		<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Aluminum	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Lead	ppm	ASTM D5185m	>4	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Tin	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0





ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>0</b>	0	0
Calcium	ppm	ASTM D5185m		<b>0</b>	0	8
Phosphorus	ppm	ASTM D5185m		<b>69</b>	80	104
Zinc	ppm	ASTM D5185m		<b>7</b>	2	5
Sulfur	ppm	ASTM D5185m		<b>603</b>	698	777

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>45	<b>5</b>	2	<1
Sodium	ppm	ASTM D5185m		<b>8</b>	11	5
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Water	%	ASTM D6304	>0.6	<b>0.002</b>	0.003	0.003
ppm Water	ppm	ASTM D6304		<b>25</b>	27	33.0

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	---	● 4102	399
Particles >6µm		ASTM D7647	>320	---	▲ 842	117
Particles >14µm		ASTM D7647	>80	---	27	11
Particles >21µm		ASTM D7647	>20	---	5	2
Particles >38µm		ASTM D7647	>4	---	0	0
Particles >71µm		ASTM D7647	>3	---	0	0
Oil Cleanliness		ISO 4406 (c)	>18/15/13	---	▲ 19/17/12	16/14/11

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.137</b>	0.129	0.199


# OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	102	98.9	98.8
Visc @ 100°C	cSt	ASTM D445	15.1	14.7	14.7
Viscosity Index (VI)	Scale	ASTM D2270	155	154	154

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO90002165 **Received** : 17 May 2024  
**Lab Number** : 06182943 **Tested** : 29 May 2024  
**Unique Number** : 11034269 **Diagnosed** : 29 May 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**ENERGY TRANSFER - MARCUS HOOK**  
 2ND & GREEN STREETS  
 MARCUS HOOK, PA  
 US 19061  
 Contact: CHRISTOPHER HOFFA  
 christopher.hoffa@energytransfer.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)