




OIL ANALYSIS REPORT



Machine Id
Pinconning CAT 2 Pinconning CAT 2
 Component
Biogas Engine
 Fluid
MOBIL PEGASUS 605 (--- GAL)

Sample Rating Trend



DIRT



DIAGNOSIS

▲ Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. We recommend an early resample to monitor this condition.

▲ Wear

The tin level is abnormal.

▲ Contamination

Elemental level of silicon (Si) above normal.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0840743	WC0840762	WC0840764
Sample Date	Client Info		15 May 2024	07 May 2024	19 Apr 2024
Machine Age	hrs	Client Info	48373	48182	47943
Oil Age	hrs	Client Info	1000	809	570
Oil Changed	Client Info		Changed	Not Changd	Not Changd
Sample Status			SEVERE	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method		NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>14	3	2	2
Chromium	ppm	ASTM D5185m	>3	0	<1	<1
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>5	2	1	1
Lead	ppm	ASTM D5185m	>8	0	2	0
Copper	ppm	ASTM D5185m	>5	2	2	3
Tin	ppm	ASTM D5185m	>3	▲ 3	2	2
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		65	19	88
Barium	ppm	ASTM D5185m		0	0	1
Molybdenum	ppm	ASTM D5185m		9	6	8
Manganese	ppm	ASTM D5185m		<1	<1	1
Magnesium	ppm	ASTM D5185m		39	38	62
Calcium	ppm	ASTM D5185m		1539	1597	1565
Phosphorus	ppm	ASTM D5185m		407	311	418
Zinc	ppm	ASTM D5185m		580	372	582
Sulfur	ppm	ASTM D5185m		3598	2366	3902

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>180	▲ 220	101	145
Sodium	ppm	ASTM D5185m	>20	2	0	3
Potassium	ppm	ASTM D5185m	>20	0	3	0

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0	0.1	0
Nitration	Abs/cm	*ASTM D7624		5.0	5.1	3.3
Sulfation	Abs/.1mm	*ASTM D7415		18.0	16.9	17.0


FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414		11.3	10.1	9.3
Acid Number (AN)	mg KOH/g	ASTM D8045		0.93	0.77	0.70
Base Number (BN)	mg KOH/g	ASTM D2896	7.1	4.27	4.54	4.38




OIL ANALYSIS REPORT


Non-ferrous Metals




FT-IR (Direct Trend)




Acid Number



Acid Number



Base Number




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.3	14.1	13.5

GRAPHS


Iron (ppm)




Lead (ppm)




Aluminum (ppm)




Chromium (ppm)




Copper (ppm)




Silicon (ppm)



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0840743
 Lab Number : 06183054
 Unique Number : 11034380
 Test Package : MOB 2

Received : 17 May 2024
 Tested : 21 May 2024
 Diagnosed : 21 May 2024 - Sean Felton

EDL NA Recips-Pinconning
 Pinconning Powerstation, 2403 E. Whitefeather Road
 Pinconning, MI
 US 48650
 Contact: KEVIN ACKERMAN
 kevin.ackerman@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)