




# COOLANT REPORT

Area  
**KANSAS/44/EG - EXCAVATOR**  
 Machine Id  
**20.140L [KANSAS^44^EG - EXCAVATOR]**  
 Component  
**Coolant**  
 Fluid  
**CAT EXTENDED LIFE COOLANT (ELC) (--- GAL)**

Sample Rating Trend



**NORMAL**



## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The fluid is suitable for further service.

### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

### Contaminants

There is no indication of any contamination in the coolant.

### Coolant Condition

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0918393</b>	WC0833765	WC0789912
Sample Date	Client Info		<b>08 May 2024</b>	02 Oct 2023	11 Sep 2023
Machine Age	hrs	Client Info	<b>6208</b>	5861	5806
Oil Age	hrs	Client Info	<b>6208</b>	5861	5806
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Glycol Type	FT-IR		---	---	---
Specific Gravity	*ASTM D1298		<b>1.075</b>	1.076	1.076
pH	Scale 0-14	ASTM D1287	<b>7.99</b>	8.17	8.12
Nitrites	ppm	AP-053:2009	<b>976</b>	788	448
Reserve Alkalinity	Scale 0-20	*ASTM D1121	---	---	---
Percentage Glycol	%	ASTM D3321	<b>56.1</b>	57.2	57.1
Freezing Point	°F	ASTM D3321	<b>-50</b>	-52	-52
Total Dissolved Solids			<b>411.0</b>	350.0	325.5
Carboxylate			<b>fail</b>	pass	fail

## CORROSION INHIBITORS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D6130	0	<b>2</b>	2	6
Phosphorus	ppm	ASTM D6130	0	<b>0</b>	8	0
Boron	ppm	ASTM D6130	0	<b>65</b>	67	109
Molybdenum	ppm	ASTM D6130	950	<b>669</b>	518	892

## CORROSION

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D6130	>15	<b>0</b>	0	0
Aluminum	ppm	ASTM D6130	>10	<b>0</b>	0	4
Copper	ppm	ASTM D6130	>10	<b>0</b>	<1	<1
Lead	ppm	ASTM D6130	>10	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D6130	>10	<b>0</b>	<1	0
Zinc	ppm	ASTM D6130		<b>0</b>	<1	0

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Chlorine	ppm	ASTM D6130		<b>2</b>	9	80

## CARRIER SALTS


	method	limit/base	current	history1	history2	
Sodium	ppm	ASTM D6130		<b>4341</b>	3431	5368
Potassium	ppm	ASTM D6130		<b>12</b>	16	0

## SCALE POTENTIAL

	method	limit/base	current	history1	history2	
Calcium	ppm	ASTM D6130		<b>2</b>	3	3
Magnesium	ppm	ASTM D6130		<b>&lt;1</b>	<1	0









# COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual		Red	Red	Red
Coolant Appearance	*Visual	Clear	normal	normal	normal
Color					
Bottom					

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0918393 **Received** : 17 May 2024  
**Lab Number** : 06183266 **Tested** : 24 May 2024  
**Unique Number** : 11034592 **Diagnosed** : 24 May 2024 - Jonathan Hester  
**Test Package** : COOL- ( Additional Tests: BoilingPoint, COOL, GlycolType, ICP )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**SHERWOOD CONSTRUCTION CO INC**  
 3219 WEST MAY ST  
 WICHITA, KS  
 US 67213  
 Contact: DOUG KING  
 doug.king@sherwood.net  
 T: (316)617-3161  
 F: x: