




# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**KAESER DS140 1427615 (S/N 142981)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) S-460 (--- LTR)**

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCPA016537</b>	KCP37427	KCP03581
Sample Date	Client Info		<b>01 May 2024</b>	07 May 2021	07 Nov 2017
Machine Age	hrs	Client Info	<b>43973</b>	43959	12957
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>Changed</b>	Changed	Changed
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<1	<1	2
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	0	<1
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	<1	<1	0
Aluminum	ppm	ASTM D5185m >10	<b>2</b>	<1	1
Lead	ppm	ASTM D5185m >10	<1	0	0
Copper	ppm	ASTM D5185m >50	<b>3</b>	18	9
Tin	ppm	ASTM D5185m >10	<1	0	0
Antimony	ppm	ASTM D5185m	---	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	10	0
Barium	ppm	ASTM D5185m 90	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<1	0	0
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m 90	<1	<1	0
Calcium	ppm	ASTM D5185m 2	<b>4</b>	8	0
Phosphorus	ppm	ASTM D5185m	<b>50</b>	45	144
Zinc	ppm	ASTM D5185m	<b>2</b>	<1	2
Sulfur	ppm	ASTM D5185m	<b>19469</b>	13720	10135

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>2</b>	0	2
Sodium	ppm	ASTM D5185m	<b>0</b>	<1	<1
Potassium	ppm	ASTM D5185m >20	<b>1</b>	0	7
Water	%	ASTM D6304 >0.05	<b>0.003</b>	0.009	0.010
ppm Water	ppm	ASTM D6304 >500	<b>38</b>	95.8	100






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>8364</b>	---	7599
Particles >6µm	ASTM D7647 >1300		<b>1864</b>	---	▲ 2055
Particles >14µm	ASTM D7647 >80		▲ <b>192</b>	---	▲ 207
Particles >21µm	ASTM D7647 >20		▲ <b>61</b>	---	▲ 70
Particles >38µm	ASTM D7647 >4		<b>4</b>	---	▲ 9
Particles >71µm	ASTM D7647 >3		<b>0</b>	---	▲ 3
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>20/18/15</b>	---	▲ 18/15

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.46</b>	0.508	0.636

# OIL ANALYSIS REPORT






PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.1	46.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA016537  
**Lab Number** : 06183336  
**Unique Number** : 11034662  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )  
**Received** : 17 May 2024  
**Tested** : 20 May 2024  
**Diagnosed** : 21 May 2024 - Don Baldrige

**BANKHEAD RAILWAY SERVICES - NORFOLK SOUTHERN CORP**  
 1680 MARIETTA RD NW  
 ATLANTA, GA  
 US 30318  
 Contact: BRIAN MULLINS  
 brian.mullins@nscorp.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)