

# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# 6050766 (S/N 1410)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				May2024		
CAMPLE INFORM	AATIONI		11		la facta con ed	la:-1 0
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017768		
Sample Date		Client Info		14 May 2024		
Machine Age	hrs	Client Info		36798		
Oil Age	hrs	Client Info		3940		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	10		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	<1		
Aluminum	ppm	ASTM D5185m	>10	10		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m		1		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES	le le	method	limit/base	current	history1	history2
	0.0.00	ASTM D5185m	mmbasc			
Boron	ppm			0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		1		
Calcium	ppm	ASTM D5185m		4		
Phosphorus	ppm	ASTM D5185m	500	93		
Zinc	ppm	ASTM D5185m		11		
Sulfur	ppm	ASTM D5185m		792		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	2		
Water	%	ASTM D6304	>0.05	0.003		
ppm Water	ppm	ASTM D6304	>500	28		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		9878		
Particles >6µm		ASTM D7647	>1300	1220		
Particles >14µm		ASTM D7647	>80	72		
Particles >21µm		ASTM D7647	>20	27		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/17/13		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	1.19		
	33		-	-		



## **OIL ANALYSIS REPORT**





Certificate 12367

Sample No.

Laboratory

: KCPA017768 Lab Number : 06183353 Unique Number : 11034679

Received **Tested** Diagnosed

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 17 May 2024

: 21 May 2024

: 21 May 2024 - Don Baldridge

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SMORIASI@TORTILLAKING.COM

249 23RD AVE

US 67107

T:

F:

MOUNDRIDGE, KS

Contact: S MORIASI