


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SFC 30ST 4640395 (S/N 1018)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug2017	Apr2018 Sep2020	I Oct2022 Aug2023	Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013007	KCPA005769	KCP47212
Sample Date		Client Info		23 Apr 2024	03 Aug 2023	18 Oct 2022
Machine Age	hrs	Client Info		47605	43327	40438
Oil Age	hrs	Client Info		4278	0	3187
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	<1	0
Aluminum	ppm	ASTM D5185m	>10	2	0	0
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	6	8	6
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	4	<1	6
Calcium	ppm	ASTM D5185m	2	4	0	0
Phosphorus	ppm	ASTM D5185m		8	3	2
Zinc	ppm	ASTM D5185m		37	10	28
Sulfur	ppm	ASTM D5185m		19489	18516	19937
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		2	0	6
Potassium	ppm	ASTM D5185m	>20	2	<1	0
Water	%	ASTM D6304	>0.05	0.003	0.007	0.010
ppm Water	ppm	ASTM D6304	>500	39	75.1	109.2
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6258	7225	10745
Particles >6µm		ASTM D7647	>1300	1204	<u>▲</u> 3248	<u>^</u> 2910
Particles >14μm		ASTM D7647	>80	102	<u></u> 866	<u>^</u> 298
Particles >21µm		ASTM D7647	>20	33	▲ 384	<u></u> 88
Particles >38µm		ASTM D7647	>4	2	<u>^</u> 28	<u> </u>
Particles >71µm		ASTM D7647	>3	0	1	2
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/17/14	<u>^</u> 20/19/17	<u>\$\text{21}19/15}</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06183354 Unique Number : 11034680

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA013007 Received

: 17 May 2024 **Tested** Diagnosed

: 21 May 2024 : 21 May 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) **MIRIAM HOSPITAL** 164 SUMMIT AVE

PROVIDENCE, RI US 02906 Contact: J. MCKAY

jmckay@lifespan.org

T: F:

Contact/Location: J. MCKAY - MIRPRO