




# OIL ANALYSIS REPORT

## Sample Rating Trend



## SEDIMENT



Machine Id

### 2623037 (S/N 1078)

Component

Compressor

Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

### DIAGNOSIS

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of visible silt present in the sample.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA012401	KCPA005173	KCP54650
Sample Date	Client Info		10 May 2024	28 Jun 2023	22 Jan 2023
Machine Age	hrs	Client Info	109284	103928	101222
Oil Age	hrs	Client Info	2579	0	3000
Oil Changed	Client Info		Changed	N/A	Changed
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	1	<1	0
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	<1	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	<1	0	0
Aluminum	ppm	ASTM D5185m >10	2	0	0
Lead	ppm	ASTM D5185m >10	<1	0	0
Copper	ppm	ASTM D5185m >50	2	2	4
Tin	ppm	ASTM D5185m >10	<1	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 90	35	0	12
Molybdenum	ppm	ASTM D5185m 0	<1	0	0
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m 100	38	7	9
Calcium	ppm	ASTM D5185m 0	6	0	0
Phosphorus	ppm	ASTM D5185m 0	4	0	5
Zinc	ppm	ASTM D5185m 0	3	0	1
Sulfur	ppm	ASTM D5185m 23500	22260	18931	20079

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	21	6	24
Sodium	ppm	ASTM D5185m	14	2	3
Potassium	ppm	ASTM D5185m >20	5	<1	0
Water	%	ASTM D6304 >0.05	0.013	0.009	0.006
ppm Water	ppm	ASTM D6304 >500	133	92.5	65.2




### FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		---	18565	17316
Particles >6µm	ASTM D7647	>1300	---	▲ 7043	▲ 6164
Particles >14µm	ASTM D7647	>80	---	▲ 1002	▲ 566
Particles >21µm	ASTM D7647	>20	---	▲ 199	▲ 98
Particles >38µm	ASTM D7647	>4	---	2	▲ 6
Particles >71µm	ASTM D7647	>3	---	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	---	▲ 21/20/17	▲ 21/20/16

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.43	0.41	0.47


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	49.0	48.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : KCPA012401

**Lab Number** : 06183360

**Unique Number** : 11034686

**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**Received** : 17 May 2024

**Tested** : 21 May 2024

**Diagnosed** : 21 May 2024 - Don Baldrige

**PACIFIC SOUTHWEST CONTAINER**

4530 LECHRON RD

MODESTO, CA

US 95357

Contact: J. PLANTZ

jplantz@teampsc.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)