

FUEL REPORT



Machine Id

KIOTI RX7320 PX63A0108

Diesel Fuel

Fluid No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

DIAGNOSIS

A Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of particulates present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KT0001577		
Sample Date		Client Info		13 May 2024		
Machine Age	hrs	Client Info		0		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L4.0		
Visc @ 40°C	cSt	ASTM D445	3.0	2.46		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	58.8		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	40		
Sulfur (UVF)	ppm	ASTM D5453		15		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	169		
5% Distillation Point	°C	ASTM D86		190		
10% Distill Point	°C	ASTM D86	201	200		
15% Distillation Point	°C	ASTM D86		208		
20% Distill Point	°C	ASTM D86	216	216		
30% Distill Point	°C	ASTM D86	230	231		
40% Distill Point	°C	ASTM D86	243	245		
50% Distill Point	°C	ASTM D86	255	259		
60% Distill Point	°C	ASTM D86	267	273		
70% Distill Point	°C	ASTM D86	280	287		
80% Distill Point	°C	ASTM D86	295	303		
85% Distillation Point	°C	ASTM D86		314		
90% Distill Point	°C	ASTM D86	310	324		
95% Distillation Point	°C	ASTM D86		343		
Final Boiling Point	°C	ASTM D86	341	360		
IGNITION QUALI	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	37		
Cetane Index		ASTM D4737	<40.0	48		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	<1		
Water	%	ASTM D6304	<0.05	0.003		
ppm Water	ppm	ASTM D6304	<500	33		
% Gasoline	%	*In-House	<0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT

491,520	Particle Count	т26	FLUID CLEANLI	NESS	method	limit/base	current	history1	history2
122,880	-	-24	Particles >4µm		ASTM D7647	>2500	674		
Ê 30,720	Severe	-22 8	Particles >6µm		ASTM D7647	>640	A 2583		
(m 30,720 7,680 1,920 1,920 480 480 120 120 120 30 8	Abnomial	22 (S0 4406:1999 Cleanliness 16 1410:1999 Cleanliness 16 1410:1999 Cleanliness	Particles >14µm		ASTM D7647	>80	483		
ajoju 120 480		-16 Ce	Particles >21µm		ASTM D7647	>20	<u> </u>		
ີ່ 5 120 ສ		14 anline	Particles >38µm		ASTM D7647	>4	7		
admun 30			Particles >71µm		ASTM D7647	>3	0		
2		8	Oil Cleanliness		ISO 4406 (c)	>18/16/13	A 20/19/16		
v.	4μ 6μ 14μ 21 Particle Trend	μ 38μ 71μ	HEAVY METALS		method	limit/base	current	history1	history2
6k	Ι		Aluminum	ppm	ASTM D5185m	<0.1	0		
≘ ^{5k}	4μm 6μm		Nickel	ppm	ASTM D5185m	<0.1	0		
(j ml) selbiated for the definition of the defin			Lead	ppm	ASTM D5185m	<0.1	0		
ipited 3k	Abnormal		Vanadium	ppm	ASTM D5185m	<0.1	<1		
jo ja 2k	Abnormal		Iron	ppm	ASTM D5185m	<0.1	0		
jag 2k mu 1k			Calcium	ppm	ASTM D5185m	<0.1	0		
Ok			Magnesium	ppm	ASTM D5185m	<0.1	<1		
	May13/24	May13/24	Phosphorus	ppm	ASTM D5185m	<0.1	4		
	May	May	Zinc	ppm	ASTM D5185m	<0.1	4		
1200	Water (KF)		SAMPLE IMAGE	S	method	limit/base	current	history1	history2
1000 008 000	- Severe		Color				ILSTOOR Y	no image	no image
≤ 400 200 0	-	42/51/gM	Bottom					no image	no image
	May	May	GRAPHS						
	Viscosity @ 40°C		Fuel Distillation C	irve			Pensky-Marte	ns Flash Point (°C)
6	Viscosity @ 40°C		380°C T	ırve		ې پ	" ⁰ T	ns Flash Point (°C)
6	Į			ırve		atin f	0 	ns Flash Point (°C)
6 5 ()	Viscosity @ 40°C		380°C Sample	Jrve		temperature	Base	ns Flash Point (°C)
6 5 4 (J_0()) 3 7	Į		360°C Sample	ırve		temperature	0 	ns Flash Point (
6 5 (0,0 1)) t ₅ 2	Abnormal		380°C Sample 360°C - Sample 340°C - 320°C -	irve	/	temperature	Base	ns Flash Point (
6 5 (3-0+) 5 3 2 1	Abnormal		380°C Sample 360°C - Sample 340°C - 320°C - 330°C -	irve		temperature	Base		°C)
6 5 (1,0)) 8 2 1 1 0 350 350 350 250 200	Abnormal Base Abnormal Gas Chromatography (Ge	+72E L/km CD)	380°C Sample 360°C Sample 340°C 320°C 32	Irve		50 45 44 44 32 92 92 92 15 10	GCD Spectrur		
دی 2 1 0 400 350 350 20 20 20 20 20 20 20 20 20 20 20 20 20	Abnormal Base Gas Chromatography (G GCD 10% GCD 10% GCD 90% GCD 90% GCD 90% CCC 90% CC	CD)	380°C 360°C 360°C 320°C 320°C 320°C 28	1 Madiso Rece Testo Diag ts: Fuel, <i>ice at 1-8</i>	on Ave., Cary ived : 17 ed : 21 nosed : 03 Screen) 300-237-1365	50 46 40 30 7, NC 27513 7 May 2024 1 May 2024 1 Jun 2024 - Do	GCD Spectrum	m	PCELINEW

Report Id: STEAND [WUSCAR] 06183823 (Generated: 06/04/2024 05:56:03) Rev: 1

Contact/Location: SERVICE MANAGER - STEAND