




PROBLEM SUMMARY


Area
COLD MILL/CM-3STD-1S
 Machine Id
SOUTH 3-STAND REWIND GEARBOX 1526-007-7540
 Component
Gearbox
 Fluid
PETRO CANADA ENDURATEX EP 460 (100 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS

| Sample Status | | | SEVERE | SEVERE | SEVERE |
|-----------------|--------------|-----------|------------|------------|------------|
| Particles >4µm | ASTM D7647 | >20000 | ▲ 171399 | ▲ 137609 | ▲ 173703 |
| Particles >6µm | ASTM D7647 | >5000 | ▲ 73957 | ▲ 53153 | ▲ 43353 |
| Particles >14µm | ASTM D7647 | >640 | ▲ 1929 | ▲ 1453 | ▲ 1144 |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | ▲ 25/23/18 | ▲ 24/23/18 | ▲ 25/23/17 |

Customer Id: CONMUSAL
 Sample No.: KFS0004441
 Lab Number: 06184285
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Wes Davis +1 905-569-8600 x223
wesd@wearcheck.ca


To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|-----------------|--------|------|---------|--|
| Change Filter | --- | --- | ? | We recommend you service the filters on this component. |
| Resample | --- | --- | ? | Resample in 30-45 days to monitor this situation. |
| Check Breathers | --- | --- | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. |
| Check Seals | --- | --- | ? | Check seals and/or filters for points of contaminant entry. |


HISTORICAL DIAGNOSIS

ISO




16 Apr 2024 Diag: Wes Davis
 Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report




ISO




29 Feb 2024 Diag: Wes Davis
 Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report




ISO



05 Feb 2024 Diag: Wes Davis
 Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
COLD MILL/CM-3STD-1S
 Machine Id
SOUTH 3-STAND REWIND GEARBOX 1526-007-7540
 Component
Gearbox
 Fluid
PETRO CANADA ENDURATEX EP 460 (100 GAL)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | KFS0004441 | KFS0004478 | KFS0004665 |
| Sample Date | Client Info | | 16 May 2024 | 16 Apr 2024 | 29 Feb 2024 |
| Machine Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | 0 | 0 | 0 |
| Oil Changed | Client Info | | N/A | N/A | N/A |
| Sample Status | | | SEVERE | SEVERE | SEVERE |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >0.2 | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 | |
|----------|--------|-------------|---------|-----------|----------|---|
| Iron | ppm | ASTM D5185m | >200 | 16 | 9 | 7 |
| Chromium | ppm | ASTM D5185m | >15 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >15 | 0 | <1 | 0 |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >25 | 0 | <1 | 0 |
| Lead | ppm | ASTM D5185m | >100 | 0 | <1 | 0 |
| Copper | ppm | ASTM D5185m | >200 | 0 | <1 | 0 |
| Tin | ppm | ASTM D5185m | >25 | 0 | <1 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 | |
|------------|--------|-------------|---------|--------------|----------|------|
| Boron | ppm | ASTM D5185m | 55 | 34 | 36 | 30 |
| Barium | ppm | ASTM D5185m | 0 | 0 | 0 | 0 |
| Molybdenum | ppm | ASTM D5185m | 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0 | 0 | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 2 | <1 | 1 | 0 |
| Calcium | ppm | ASTM D5185m | 6 | <1 | 1 | 0 |
| Phosphorus | ppm | ASTM D5185m | 240 | 205 | 209 | 195 |
| Zinc | ppm | ASTM D5185m | 3 | <1 | 0 | 0 |
| Sulfur | ppm | ASTM D5185m | 10310 | 8372 | 8735 | 7051 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 | |
|-----------|--------|-------------|---------|----------|----------|---|
| Silicon | ppm | ASTM D5185m | >50 | 8 | 8 | 8 |
| Sodium | ppm | ASTM D5185m | | 0 | 2 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 3 | 0 |


FLUID CLEANLINESS

| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-------------------|------------|------------|
| Particles >4µm | ASTM D7647 | >20000 | ▲ 171399 | ▲ 137609 | ▲ 173703 |
| Particles >6µm | ASTM D7647 | >5000 | ▲ 73957 | ▲ 53153 | ▲ 43353 |
| Particles >14µm | ASTM D7647 | >640 | ▲ 1929 | ▲ 1453 | ● 1144 |
| Particles >21µm | ASTM D7647 | >160 | 205 | 151 | 137 |
| Particles >38µm | ASTM D7647 | >40 | 2 | 1 | 1 |
| Particles >71µm | ASTM D7647 | >10 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >21/19/16 | ▲ 25/23/18 | ▲ 24/23/18 | ▲ 25/23/17 |


FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 | |
|------------------|----------|------------|---------|-------------|----------|------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.5 | 0.48 | 0.53 | 0.60 |


▲ Particle Trend




▲ Particle Trend



Acid Number



Viscosity @ 40°C



| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.2 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 452 | 427 | 434 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : KFS0004441

Lab Number : 06184285

Unique Number : 11035611

Test Package : IND 2 (Additional Tests: PrtCount)

Received : 20 May 2024

Tested : 21 May 2024

Diagnosed : 21 May 2024 - Wes Davis

CONSTELLIUM

4805 SECOND STREET

MUSCLE SHOALS, AL

US 35661

Contact: Randy Nichols

randall.nichols@constellium.com

T: (256)386-6956

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)