OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Area
Utility
Machine Id
Atlas Copco FHG82CK01 Main Fermentation Air, Compressor
Component
Air Compressor
Fluid
MOBIL DTE OIL HVY MEDIUM (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor. (Customer Sample Comment: Was not running)

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0916405**	WC0726021	WC0679868
Sample Date		Client Info		**16 May 2024**	23 Aug 2022	05 Apr 2022
Machine Age	yrs	Client Info		**0**	0	0
Oil Age	yrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**NORMAL**	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>70	**0**	0	0
Chromium	ppm	ASTM D5185m	>15	**0**	0	0
Nickel	ppm	ASTM D5185m	>6	**0**	0	0
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	<1	<1
Aluminum	ppm	ASTM D5185m	>10	**0**	<1	0
Lead	ppm	ASTM D5185m	>20	**<1**	1	1
Copper	ppm	ASTM D5185m	>80	**3**	4	4
Tin	ppm	ASTM D5185m	>15	**0**	0	0
Antimony	ppm	ASTM D5185m		**---**	---	---
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	<1	2
Barium	ppm	ASTM D5185m		**0**	0	0
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	0	0
Magnesium	ppm	ASTM D5185m		**0**	0	0
Calcium	ppm	ASTM D5185m		**0**	2	0
Phosphorus	ppm	ASTM D5185m		**115**	114	106
Zinc	ppm	ASTM D5185m		**77**	74	77
Sulfur	ppm	ASTM D5185m		**1325**	1135	1046

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>12	**<1**	<1	0
Sodium	ppm	ASTM D5185m		**<1**	<1	0
Potassium	ppm	ASTM D5185m	>20	**0**	0	<1
Water	%	ASTM D6304	>0.1	**0.00**	0.003	0.00
ppm Water	ppm	ASTM D6304	>1000	**0**	29.2	0.00

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	**4517**	1513	5079
Particles >6µm		ASTM D7647	>2500	**745**	325	762
Particles >14µm		ASTM D7647	>320	**41**	26	54
Particles >21µm		ASTM D7647	>80	**10**	5	15
Particles >38µm		ASTM D7647	>20	**1**	0	2
Particles >71µm		ASTM D7647	>4	**0**	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	**19/17/13**	18/16/12	20/17/13

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		**0.11**	0.13	0.13

OIL ANALYSIS REPORT

Water (KF)



Particle Trend



Water (KF)

Severe
Abnormal
Water (ppm)
Oct9/19
Feb25/20
Sep15/20
Mar22/21
Oct6/21
Apr5/22
Aug23/22

Viscosity @ 40°C



Particle Trend

4µm
6µm
14µm
number of particles (1 ml)
Oct9/19
Feb25/20
Sep15/20
Mar22/21
Oct6/21
Apr5/22
Aug23/22

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	65.1	**61.9**	62.3	61.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0916405
Lab Number : 06184305
Unique Number : 11035631
Test Package : IND 2 (Additional Tests: KF, PrtCount)

Received : 20 May 2024
Tested : 21 May 2024
Diagnosed : 22 May 2024 - Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NOVOZYMES
P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD
FRANKLINTON, NC
US 27525
Contact: BRUCE THOMAS
brct@novozymes.com
T: (919)494-3146
F: (919)494-3456