




PROBLEM SUMMARY


Machine Id
MV15 PUMP 151 (S/N 200001524)
 Component
Vacuum Pump
 Fluid
USPI VAC 100 (--- GAL)

Sample Rating Trend




COMPONENT CONDITION SUMMARY

▲ Ferrous Alloys



▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	NORMAL	ABNORMAL
Iron	ppm	ASTM D5185m >20	▲ 97	7	17
Particles >4µm		ASTM D7647 >5000	▲ 119895	593	▲ 85897
Particles >6µm		ASTM D7647 >1300	▲ 30506	137	▲ 28626
Particles >14µm		ASTM D7647 >160	▲ 355	12	▲ 625
Oil Cleanliness		ISO 4406 (c) >19/17/14	▲ 24/22/16	16/14/11	▲ 24/22/16

Customer Id: TYSCHIBRU
 Sample No.: USPM36185
 Lab Number: 06184323
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

NORMAL



13 Feb 2024 Diag: Doug Bogart

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



ISO



03 Nov 2023 Diag: Doug Bogart

We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



NORMAL



26 Sep 2023 Diag: Doug Bogart

Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
MV15 PUMP 151 (S/N 200001524)
 Component
Vacuum Pump
 Fluid
USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

Wear

The iron level is severe.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		USPM36185	USPM30012	USPM31222
Sample Date	Client Info		15 May 2024	13 Feb 2024	03 Nov 2023
Machine Age	days	Client Info	0	0	0
Oil Age	days	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	NORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	▲ 97	7	17
Chromium	ppm	ASTM D5185m >20	0	0	0
Nickel	ppm	ASTM D5185m >20	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >20	0	<1	0
Lead	ppm	ASTM D5185m >20	0	0	0
Copper	ppm	ASTM D5185m >20	0	0	0
Tin	ppm	ASTM D5185m >20	0	<1	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m 0	1	<1	0
Calcium	ppm	ASTM D5185m 0	0	3	0
Phosphorus	ppm	ASTM D5185m 1800	689	804	898
Zinc	ppm	ASTM D5185m 0	4	0	4
Sulfur	ppm	ASTM D5185m 0	130	67	79

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	6	4	8
Sodium	ppm	ASTM D5185m	7	1	<1
Potassium	ppm	ASTM D5185m >20	3	<1	<1
Water	%	ASTM D6304 >.1	0.042	0.025	0.011
ppm Water	ppm	ASTM D6304 >1000	423	254	116.7

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	▲ 119895	593	▲ 85897
Particles >6µm	ASTM D7647	>1300	▲ 30506	137	▲ 28626
Particles >14µm	ASTM D7647	>160	▲ 355	12	▲ 625
Particles >21µm	ASTM D7647	>40	22	3	▲ 76
Particles >38µm	ASTM D7647	>10	0	0	3
Particles >71µm	ASTM D7647	>3	0	0	1
Oil Cleanliness	ISO 4406 (c)	>19/17/14	▲ 24/22/16	16/14/11	▲ 24/22/16

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.05	0.35	0.15	0.21



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	91	98.3	96.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------






Color



Bottom



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USPM36185
 Lab Number : 06184323
 Unique Number : 11035649
 Test Package : IND 2

Received : 20 May 2024
 Tested : 21 May 2024
 Diagnosed : 22 May 2024 - Jonathan Hester

TYSON FOODS BRUSS-CHICAGO
 3548 N KOSTNER AVE
 CHICAGO, IL
 US 60641
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: