

OIL ANALYSIS REPORT

Area S-460 Machine to KAESER 1258 - ARTRAGEANS

Component Compressor

Fluid KAESER SIGMA (OEM) S-460 (1 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





NORMAL

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0919505		
Sample Date		Client Info		03 May 2024		
Machine Age	hrs	Client Info		356		
Oil Age	hrs	Client Info		356		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	<1		
Aluminum	ppm	ASTM D5185m	>10	2		
Lead	ppm	ASTM D5185m	>10	1		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>10	1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	15		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	90	57		
Calcium	ppm	ASTM D5185m	2	4		
Phosphorus	ppm	ASTM D5185m		2		
Zinc	ppm	ASTM D5185m		4		
Sulfur	ppm	ASTM D5185m		20231		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		7		
Potassium	ppm	ASTM D5185m	>20	3		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.35		

Sample Rating Trend




Base

Abnormal 40 38 May3/24

42

ş

OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
May3/24	Appearance	scalar	*Visual	NORML	NORML			
×	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.05	NEG			
1	Free Water	scalar	*Visual		NEG			
	FLUID PROPERT	TIES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445	46	44.6			
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2	
May324 +	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Metal			May3/24				
	⊵ Viscosity @ 40°C			Ma	Acid Number			
	Abnormal Base Base 40 35 40 40 40			924 	50 40 20 10 00			
Laboratory Sample No. Lab Number Unique Number	: WC0919505 : <mark>06184383</mark> : 11035709	Recei Teste	Madison Ave., Cary, NC 27513 Received : 20 May 2024 Tested : 21 May 2024 Diagnosed : 21 May 2024 - Wes Davis			DELTA INDUSTRIES - VOL 31632 N ELLIS D VOLO, US 6007 Contact: Service Manage		
Certificate 12367 Test Package : IND 2 Contact: Service To discuss this sample report, contact Customer Service at 1-800-237-1369. - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Contact: Service Test Package - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Contact: Service								

50

Contact/Location: Service Manager - UCDELVOL Page 2 of 2