


OIL ANALYSIS REPORT

KAESER S-460 **KAESER 5102133 - PANDUIT**

Component Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UDI0000229	UCH05450264	UCH05342734
Sample Date		Client Info		06 May 2024	10 Jan 2022	27 Jul 2021
Machine Age	hrs	Client Info		89169	83571	82539
Oil Age	hrs	Client Info		2000	1048	4175
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	<1	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	6	2	5
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	21	<1
Barium	ppm	ASTM D5185m	90	33	13	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	31	56	0
Calcium	ppm	ASTM D5185m	2	4	2	0
Phosphorus	ppm	ASTM D5185m		3	11	5
Zinc	ppm	ASTM D5185m		2	4	0
Sulfur	ppm	ASTM D5185m		17448	16827	15585
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	<1	2
Sodium	ppm	ASTM D5185m		2	32	0
Potassium	ppm	ASTM D5185m	>20	2	4	0
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.34	0.369



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.4	44.7	44.8
SAMPLE IMAGES		method	limit/base	current	history1	history2


Color


















Certificate 12367

Laboratory Sample No.

Lab Number : 06184392 Unique Number : 11035718 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UDI0000229 Received : 20 May 2024

Tested : 21 May 2024 Diagnosed : 21 May 2024 - Wes Davis

DELTA INDUSTRIES - DOWNERS GROVE 2201 CURTISS STREET

DOWNERS GROVE, IL US 60515

Contact: MICHAEL FERRIS

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (630)960-3931 Contact/Location: MICHAEL FERRIS - UCDELDOW

Report Id: UCDELDOW [WUSCAR] 06184392 (Generated: 05/21/2024 16:21:15) Rev: 1