


# **OIL ANALYSIS REPORT**

# SYNOIL 8K **CURTIS 16B00007 - ROCKFORD SPECIALTIES** Component Compressor





## Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the


## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCZ06184423		
Sample Date		Client Info		07 May 2024		
Machine Age	hrs	Client Info		28256		
Oil Age	hrs	Client Info		2000		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	٧	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	6		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>25	<1		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0.3	0		
Barium	ppm	ASTM D5185m	0.3	0		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m	0.9	1		
Magnesium	ppm	ASTM D5185m	0.2	<1		
Calcium	ppm	ASTM D5185m	0.1	4		
Phosphorus	ppm	ASTM D5185m	429	352		
Zinc	ppm	ASTM D5185m	0.3	38		
Sulfur	ppm	ASTM D5185m	1336	5		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.622	0.19		




## **OIL ANALYSIS REPORT**




VISUAL		method	limit/base	current	history1	history2		
White Metal	scalar	*Visual	NONE	NONE				
Yellow Metal	scalar	*Visual	NONE	NONE				
Precipitate	scalar	*Visual	NONE	NONE				
Silt	scalar	*Visual	NONE	NONE				
Debris	scalar	*Visual	NONE	LIGHT				
Sand/Dirt	scalar	*Visual	NONE	NONE				
Appearance	scalar	*Visual	NORML	NORML				
Odor	scalar	*Visual	NORML	NORML				
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG				
Free Water	scalar	*Visual		NEG				
FLUID PROPERT	TES	method	limit/base	current	history1	history2		
Visc @ 40°C	cSt	ASTM D445	44.32	45.1				
SAMPLE IMAGES	3	method	limit/base	current	history1	history2		
Color					no image	no image		
Bottom					no image	no image		
GRAPHS								

# Ferrous Alloys











Certificate 12367

Laboratory

**Sample No.** : UCZ06184423 Lab Number : 06184423 Unique Number : 11035749

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received : 20 May 2024 Tested Diagnosed

: 21 May 2024

: 21 May 2024 - Wes Davis

227 AMBROSIO DR, SUITE A GURNEE, IL

**ZORN COMPRESSOR EQUIPMENT** 

US 60031 Contact: Rachel Pesnikov

rachel.pesnikov@zornair.com T: (847)599-1333

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: x: