

OIL ANALYSIS REPORT

Sample Rating Trend

VISCOSITY

Machine Id

8104411214001 (S/N 810441214001) Component Gearbox

Fluid SHELL OMALA 150 (2 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


Viscosity of sample indicates oil is within ISO 220 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0884857		
Sample Date		Client Info		04 Jan 2024		
Machine Age	mths	Client Info		0		
Oil Age	mths	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ATTENTION		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	6		
Chromium	ppm	ASTM D5185m	>15	<1		
Nickel	ppm	ASTM D5185m	>15	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>25	2		
Lead	ppm	ASTM D5185m	>100	<1		
Copper	ppm	ASTM D5185m	>200	1		
Tin	ppm	ASTM D5185m	>25	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	6.2	<1		
Barium	ppm	ASTM D5185m	0.0	4		
Molybdenum	ppm	ASTM D5185m	0	<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	0	<1		
Calcium	ppm	ASTM D5185m	0.0	15		
Phosphorus	ppm	ASTM D5185m	512	193		
Zinc	ppm	ASTM D5185m	3.8	23		
Sulfur	ppm	ASTM D5185m	8167	12344		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	2		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.44		



OIL ANALYSIS REPORT

VISUAL





VISUAL							
White Metal	scalar	*Visual	NONE	NONE			
Yellow Metal	scalar	*Visual	NONE	NONE			
Precipitate	scalar	*Visual	NONE	NONE			
Silt	scalar	*Visual	NONE	NONE			
Debris	scalar	*Visual	NONE	LIGHT			
Sand/Dirt	scalar	*Visual	NONE	NONE			
Appearance	scalar	*Visual	NORML	NORML			
Odor	scalar	*Visual	NORML	NORML			
Emulsified Water	scalar	*Visual	>0.2	NEG			
Free Water	scalar	*Visual		NEG			
FLUID PROPERT	IES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	150	222.6			
SAMPLE IMAGES	8	method	limit/base	current	history1	history2	
Color				•	no image	no image	
Bottom					no image	no image	
GRAPHS							
Ferrous Alloys							
2 0 4774 LEP			Jan4/24				
Non-ferrous Metals	5						
8 copper 6 copper 6 copper 1 copp			Jan4/24				
Viscosity @ 40°C				Acid Number			
220 -			(B) 0.50 (C) 0.40 (C) 0.30 (C) 0.40 (C)				
200 -			2 U.4U E n 21				
200 - 180 - Abnormal 160 - Base			을 0.30 은 0.20	1			
160 - Base 140 - Abnormal				ļ			
120			0.00				
Jan4/24			Jan 4/24	Jan4/24		Jan4/24	
WearCheck USA - 501 Madison Ave., Cary, NC 27513 WC0884857 Received : 20 May 2024 06184502 Tested : 29 May 2024 11035828 Diagnosed : 29 May 2024 - Jonathan Hester ND 2 Interformer Service at 1-800-237-1369. e outside of the ISO 17025 scope of accreditation.					SOLVAY SPARTANBURG 399 SIMS CHAPEL RD SPARTANBURG, SC US 29306 Contact: GREG BLACK gregory.black@syensqo.com T: (864)594-3270		

To discuss this sample report, co * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

cSt (40°C)

Laboratory Sample No. Lab Number **Unique Number Test Package**

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: SOLSPA [WUSCAR] 06184502 (Generated: 05/29/2024 16:21:56) Rev: 1

Certificate L2367

Contact/Location: GREG BLACK - SOLSPA

F: (864)573-6972