

# **OIL ANALYSIS REPORT**


[WO# 1830786]

# Receiving Elevator (S/N 355089083A)

**Gear Reducer** 

Fluid

**CERTIFIED CERTOP FG 90 (15 QTS)** 



Sample Rating Trend



## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2020 J	ul2021 Feb2022 Aug	2022 Feb2023 Aug2023	Feb 2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0887417	WC0887416	WC0768399
Sample Date		Client Info		09 May 2024	09 Feb 2024	20 Nov 2023
Machine Age	yrs	Client Info		16	34	34
Oil Age	yrs	Client Info		1	1	0
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	<1	1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>10	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	<1	1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>50	2	<1	<1
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		279	286	322
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		168	470	251
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	9	9	10
Sodium	ppm	ASTM D5185m		1	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	1
Water	%	ASTM D6304	>0.1	0.001	0.001	0.002
ppm Water	ppm	ASTM D6304	>1000	10	9	24
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	2344	2071	4787
Particles >6µm		ASTM D7647	>5000	845	656	944
Particles >14µm		ASTM D7647	>640	85	85	114
Particles >21µm		ASTM D7647	>160	9	12	23
Particles >38μm		ASTM D7647	>40	0	0	0
Particles >71μm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	18/17/14	18/17/14	19/17/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.84	0.88	0.74



# **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

Lab Number : 06184976 Unique Number : 11036302

: WC0887417

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received **Tested** Diagnosed Test Package : IND 2 ( Additional Tests: KF, PrtCount )

: 20 May 2024 : 22 May 2024

: 22 May 2024 - Wes Davis

US 05488 Contact: MATT BOYLE matthew\_boyle@cargill.com T: (802)782-7638

149 JONERGIN DRIVE

SWANTON, VT

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: