

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

1432942 (S/N 3613465)

Component Compressor Fluid KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

A Wear

The iron level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014478	KCP46128	
Sample Date		Client Info		13 May 2024	21 Sep 2022	
Machine Age	hrs	Client Info		80628	79778	
Oil Age	hrs	Client Info		850	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<mark>▲</mark> 80	4	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm		>50	10	4	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		1	<1	
Magnesium	ppm	ASTM D5185m		2	3	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m	500	515	331	
Zinc	ppm	ASTM D5185m		399	183	
Sulfur	ppm	ASTM D5185m		2286	6069	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		3	0	
Potassium	ppm	ASTM D5185m	>20	2	1	
Water	%	ASTM D6304	>0.05	0.006	0.011	
ppm Water	ppm	ASTM D6304	>500	61	112.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		112229	21965	
Particles >6µm		ASTM D7647	>1300	<u> </u>	6404	
Particles >14µm		ASTM D7647	>80	▲ 234	▲ 1163	
Particles >21µm		ASTM D7647	>20	<u> </u>	▲ 476	
Particles >38µm		ASTM D7647	>4	0	▲ 69	
Particles >71µm		ASTM D7647	>3	0	▲ 3	
Oil Cleanliness		ISO 4406 (c)	>/17/13	o ▲ 24/22/15	▲ 22/20/17	
FLUID DEGRADA		method	limit/base	current	history1	history2
				1.60		
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	1.00	1.28	




4000 2000

Abnormal n Sep21/22

Built for a lifetime."

OIL ANALYSIS REPORT



VISUA	L	method	limit/base	current	history1	history2
White Me	etal scalar	*Visual	NONE	NONE	NONE	
Yellow M	letal scalar	*Visual	NONE	NONE	NONE	
Precipita	te scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	
Sand/Dir		*Visual	NONE	NONE	NONE	
		*Visual	NORML	NORML	NORML	
FZIE Appeara	scalar	*Visual	NORML	NORML	NORML	
Emulsifie		*Visual	>0.05	NEG	NEG	
Free Wa		*Visual		NEG	NEG	
FLUID	PROPERTIES	method	limit/base	current	history1	history2
Visc @ 4	l0°C cSt	ASTM D445	46	46.2	46.5	
SAMP	LE IMAGES	method	limit/base	current	history1	history2
+7/E L/APW						no image
Bottom						no image
GRAP						
A Ferrous	s Alloys		491,52	Particle Count		т26
	iron	- the second s	101,02			20
5	• chromium • nickel	and the second se	122,88			-24
5 <u></u>			30,72			-22
20						
0 L			7,68			-20 8
Sep 21/22			May13/24 s (per 1 ml	0-		-18 4406
			0			+20 ISO 4406:1999 Cleanliness Code +16 Cleanliness Code +12 +12
NON-TE 10	rrous Metals		offied #8			Clean
	copper		ng 12	0-	1	-14 8
	lead tin		unu 3	0		Code
E b 4						12
2				⁸ Bibreaemal	\backslash	-10
			24	2-		-8
м. Sep21/22			May13/24			
	ty @ 4090		N		14µ 21µ	38µ 71µ
VISCOSI 55 T	ty @ 40°C			Acid Number		
Abnormal			.2. (0) 1. 0. 9. 9. 9. 9. 9. 9. 9. 9. 9. 9. 9. 9. 9.	Base		
ల్ల ⁵⁰			X 1.	5 - 0		
() 50 () () () () () () () () () () () () () (0		
Abnormal			N P	5-		
40						
лс.ст. Sep21/22			May13/24	Sep 21/22		May13/24
cini Seg			Mar	Sel		May
Laboratory : WearChed Sample No. : KCPA014. Lab Number : 06184991 Unique Number : 11036317 Test Package : IND 2 (Ac To discuss this sample report, contact Cus * - Denotes test methods that are outside of	Teste Diagr Iditional Tests: KF, F stomer Service at 1-8	ived : 20 ed : 22 nosed : 22 PrtCount) 800-237-1368) May 2024 2 May 2024 May 2024 - Jona 9.			COOPERAGE DL FERRY RD NAPA, CA US 94558 rvice Manager T:
Statements of conformity to specifications				rule (JCGM 106:	2012)	F:

Report Id: DEMNAP [WUSCAR] 06184991 (Generated: 05/22/2024 14:53:55) Rev: 1

Contact/Location: Service Manager - DEMNAP