

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 6863036

Component Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012365		
Sample Date		Client Info		07 May 2024		
Machine Age	hrs	Client Info		8152		
Oil Age	hrs	Client Info		1090		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel		ASTM D5185m	>3	0		
	ppm			-		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm		>50	4		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	9		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	100	69		
Calcium	ppm	ASTM D5185m	0	0		
Phosphorus	ppm	ASTM D5185m	0	<1		
Zinc	ppm	ASTM D5185m	0	0		
Sulfur	ppm	ASTM D5185m	23500	23489		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		33		
Potassium	ppm	ASTM D5185m	>20	8		
Water	%	ASTM D6304	>0.05	0.011		
ppm Water	ppm	ASTM D6304	>500	118		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		9787		
Particles >6µm		ASTM D7647	>1300	815		
Particles >14µm		ASTM D7647	>80	58		
Particles >21µm		ASTM D7647	>20	19		
Particles >38µm		ASTM D7647	>4	2		
Particles >71µm		ASTM D7647		0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/17/13		
FLUID DEGRADA	TIO <u>N</u>	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.38		
(•)	3 9		-			



OIL ANALYSIS REPORT





5

	VISUAL		method				history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
7/24 -	Appearance	scalar	*Visual	NORML	NORML		
May7/24	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.05	NEG		
	Free Water	scalar	*Visual	, 0100	NEG		
	FLUID PROPE			limit/booo			_
			method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	45	50.4		
	SAMPLE IMAG	ES	method	limit/base	current	history1	history2
May7/24	Color					no image	no image
	Bottom					no image	no image
	GRAPHS						
	Ferrous Alloys				Particle Count		
	¹⁰			491,52	I		T ²⁶
	8 - Iron chromium			122,88	0+		-24
10	E 6 - nickel						
р. й. б.				30,72	0-		-22
	2			7,68	0		-20 -
	124						
	May7/24			May7/24 (per 1 ml)			-18
	Non-ferrous Me	tale		·미 48		N	16
	10 _T			of par			- Contraction
*************	8 - copper			+2/L/ver of particles (part of million 1.92	0-	1	14 5
	E 6 - tin				0-	1	-18 - -18 - -16 - -14 - -14 - -14 - -12 - -12 -
	d 4						12
Υ. Γ	2				⁸ Bibrear mal		-10
	0			4	_		
-	May7/24			May7/24	2-		
				×	0 4// 6//	14μ 21μ	38µ 71µ
	Viscosity @ 40°	С			Acid Number	1 µr 2 1µr	50µ 11µ
	60 Severe				Basermal		
	55 - C			HOX 0.9			
	² 50 − ⁹			ຍິ 0.7	2		
	表 45 Abnormal				8		
	40 - Severe			(B) H0.9 (B)	4		
	35				and a		
	May7/2			May7/24	May7/24		Mav7/24
זימ בי	Z						_
Laboratory Sample No. Lab Number Unique Number Test Package	: WearCheck USA - 5 : KCPA012365 : 06185010	Rece Teste Diagr	ived : 20 ed : 22 nosed : 22	r, NC 27513) May 2024 2 May 2024 May 2024 - Jona	than Hester	450	POMPS TIRES 00 E 51ST AVE DENVER, CC US 80216 ervice Manager

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: POMDEN [WUSCAR] 06185010 (Generated: 05/22/2024 15:16:34) Rev: 1

Contact/Location: Service Manager - POMDEN Page 2 of 2

F: