


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# KAESER BSD 60T 6090053 (S/N 1158)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2018 Mar2	019 Mar2020 Aug2020 Mar2	021 Nov2021 Jul2022 May2023 Nov2	023 May2024	
SAMPLE INFORM	/ATION	method	limit/base	current	history1	history2
	717711011		IIIIIIIIIII		•	•
Sample Number		Client Info		KCPA014459	KCPA011819	KCP55458
Sample Date		Client Info		13 May 2024	27 Nov 2023	11 May 2023
Machine Age	hrs	Client Info		28970	26973	24614
Oil Age	hrs	Client Info		1998	0	3000
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	<1
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	<1	1
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	73	53	60
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	86	79	96
Calcium	ppm	ASTM D5185m	0	<1	3	0
Phosphorus	ppm	ASTM D5185m	0	0	2	0
Zinc	ppm	ASTM D5185m	0	0	0	5
Sulfur	ppm	ASTM D5185m	23500	22362	17886	22691
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		11	13	17
Potassium	ppm	ASTM D5185m	>20	2	1	4
Water	%	ASTM D6304	>0.05	0.016	0.004	0.025
ppm Water	ppm	ASTM D6304	>500	167	47	250.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		1349	8574	11480
Particles >6µm		ASTM D7647	>1300	292	<u>4</u> 2479	<b>▲</b> 4813
Particles >14µm		ASTM D7647	>80	14	<u>194</u>	<b>▲</b> 360
Particles >21μm		ASTM D7647	>20	3	<u></u> 54	<b>△</b> 59
Particles >38µm		ASTM D7647	>4	0	2	4
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/15/11	<u>^</u> 20/18/15	<u>^</u> 21/19/16
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
A ! I A ! (A N I)	1/011/	ACTA DOCAT	4.0	0.20	0.00	0.25

Acid Number (AN)

mg KOH/g ASTM D8045 1.0


0.36

0.38

0.35



## **OIL ANALYSIS REPORT**





4k



Laboratory Sample No.

Lab Number

: 06185026 Unique Number : 11036352

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA014459 Received : 20 May 2024

**Tested** : 22 May 2024 Diagnosed

: 22 May 2024 - Jonathan Hester

Ĕ0.72 흔 0.48

≥ 0.24 0.00 G

> **AMAZON DEN2** 22205 E 19TH AVE AURORA, CO US 80019 Contact: Service Manager

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - AMAAUR

T:

F: