


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

GEA K201A

Screw Compressor

{not provided} (300 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. There is a moderate amount of visible silt present in the sample.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in

			Feb 2024	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO90003164	TO90003228	
Sample Date		Client Info		30 Apr 2024	14 Feb 2024	
Machine Age	hrs	Client Info		9730	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Not Changd	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>60	8	4	
Chromium	ppm	ASTM D5185m		0	<1	
Nickel	ppm	ASTM D5185m		<1	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		<1	0	
Aluminum	ppm	ASTM D5185m	>5	1	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m		2	0	
Tin	ppm	ASTM D5185m	>15	2	<1	
Vanadium	ppm	ASTM D5185m	>10	0	0	
Cadmium		ASTM D5185m		0	0	
	ppm	ASTIVI DSTOSIII		U		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		<1	2	
Calcium	ppm	ASTM D5185m		15	16	
Phosphorus	ppm	ASTM D5185m		25	10	
Zinc	ppm	ASTM D5185m		7	7	
Sulfur	ppm	ASTM D5185m		58	6	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	11	8	
Sodium	ppm	ASTM D5185m		2	0	
Potassium	ppm	ASTM D5185m	>20	2	0	
Water	%	ASTM D6304	>0.1	0.025	0.033	
ppm Water	ppm	ASTM D6304	>1000	251	337	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u> </u>	▲ 57782	
Particles >6µm		ASTM D7647	>2500	20382	△ 13249	
Particles >14μm		ASTM D7647	>320	218	△ 325	
Particles >21µm		ASTM D7647	>80	26	30	
Particles >38µm		ASTM D7647	>20	0	1	
Particles >71μm		ASTM D7647	>4	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>4</u> 24/22/15	△ 23/21/16	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.039	0.046	



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

: TO90003164 Lab Number : 06185077

Unique Number : 11036403

Received : 20 May 2024 **Tested** : 22 May 2024

Diagnosed : 22 May 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

473 CR 118

PECOS, TX

Contact: Service Manager

US 79772