

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Machine Id

GEA C-1370 Screw Compressor Fluid TULCO LUBSOIL SYN RL WI 100 (300 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO20000425	TO90003233	
Sample Date		Client Info		02 Apr 2024	13 Feb 2024	
Machine Age	hrs	Client Info		700	0	
Oil Age	hrs	Client Info		700	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>60	2	12	
Chromium	ppm	ASTM D5185m	>4	0	<1	
Nickel	ppm	ASTM D5185m		<1	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>5	<1	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>30	2	0	
Tin	ppm	ASTM D5185m	>15	1	2	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		0	1	
Calcium	ppm	ASTM D5185m		0	18	
Phosphorus	ppm	ASTM D5185m	1500	1566	14	
Zinc	ppm	ASTM D5185m		0	8	
Sulfur	ppm	ASTM D5185m		32	0	
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	2	2	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	2	0	
Water	%	ASTM D6304	>2.26	0.029	0.029	
ppm Water	ppm	ASTM D6304	>22600	292	292	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u> </u>	▲ 52806	
Particles >6µm		ASTM D7647	>2500	<u> </u>	1 3261	
Particles >14µm		ASTM D7647	>320	233	5 40	
Particles >21µm		ASTM D7647	>80	39	1 29	
Particles >38µm		ASTM D7647	>20	1	2	
Particles >71µm		ASTM D7647	>4	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	4 /21/15	▲ 23/21/16	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.04	0.013	0.046	


Contact/Location: Service Manager - KINBAL Page 1 of 2




OIL ANALYSIS REPORT







leb1



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: KINBAL [WUSCAR] 06185083 (Generated: 05/22/2024 15:22:40) Rev: 1

Certificate 12367

Laboratory

Sample No.

Contact/Location: Service Manager - KINBAL Page 2 of 2

T:

F: