


OIL ANALYSIS REPORT

HODGE SYN KAISHAN 112009824US01

Component Compressor



Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UHC06185134	UCH06095652	
Sample Date		Client Info		03 May 2024	20 Feb 2024	
Machine Age	hrs	Client Info		15039	13232	
Oil Age	hrs	Client Info		2922	1200	
Oil Changed		Client Info		N/A	Not Changd	
Sample Status				NORMAL	ATTENTION	
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m		<1	0	
Aluminum	ppm	ASTM D5185m	>25	1	0	
Lead	ppm	ASTM D5185m	>25	<1	0	
Copper	ppm	ASTM D5185m	>50	<1	<1	
Tin	ppm	ASTM D5185m	>15	<1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m		0	0	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m		392	379	
Zinc	ppm	ASTM D5185m		9	0	
Sulfur	ppm	ASTM D5185m		0	0	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	1	
Sodium	ppm	ASTM D5185m		0	<1	
Potassium	ppm	ASTM D5185m	>20	1	<1	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.13	0.13	





OIL ANALYSIS REPORT


















Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06185134

Unique Number : 11036460

: UHC06185134

Received : 20 May 2024 **Tested** : 21 May 2024

Diagnosed : 22 May 2024 - Sean Felton

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ATLANTA AIR COMPRESSOR

123 MERCHANTS PARK DR HOSCHTON, GA

US 30548 Contact: Derik Bray

Derik@atlantaaircompressor.com T: (470)252-9952

F: x: