


OIL ANALYSIS REPORT

NOT GIVEN KAISHAN 071808812U

Component Compressor



Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UHC06185173	UCH06031697	
Sample Date		Client Info		26 Mar 2024	25 Oct 2023	
Machine Age	hrs	Client Info		11250	10792	
Oil Age	hrs	Client Info		0	2940	
Oil Changed		Client Info		Not Changd	Changed	
Sample Status				NORMAL	NORMAL	
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	2	
Chromium	ppm	ASTM D5185m		<1	<1	
Nickel	ppm	ASTM D5185m	210	0	<1	
Titanium	ppm	ASTM D5185m		<1	<1	
Silver	ppm	ASTM D5185m		<1	0	
Aluminum	ppm	ASTM D5185m	>25	1	1	
Lead	ppm	ASTM D5185m	>25	- <1	<1	
Copper	ppm	ASTM D5185m	>50	1	<1	
Tin	ppm	ASTM D5185m	>15	<1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		12	11	
Molybdenum	ppm	ASTM D5185m		0	<1	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m		<1	0	
Calcium	ppm	ASTM D5185m		0	<1	
Phosphorus	ppm	ASTM D5185m		306	34	
Zinc	ppm	ASTM D5185m		1	8	
Sulfur	ppm	ASTM D5185m		461	0	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	8	11	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	1	1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.54	0.30	





OIL ANALYSIS REPORT















Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06185173

: UHC06185173 Unique Number : 11036499

Received : 20 May 2024 **Tested** : 21 May 2024 Diagnosed

: 22 May 2024 - Sean Felton

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ATLANTA AIR COMPRESSOR

123 MERCHANTS PARK DR HOSCHTON, GA

US 30548 Contact: Derik Bray

Derik@atlantaaircompressor.com T: (470)252-9952

F: x: