


## **FUEL REPORT**

# **WJB Dorn VA Medical Center 1305** [WJB Dorn VA Medical Center 1305] BLDG 21 BOILER 1

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (





DIAGNOSIS	
Recommendation  No corrective action is recommended at this time All laboratory tests indicate that this sample mee specifications for No.2 ultra-low-sulfur diesel fuel	ts
Corrosion All metal levels are normal indicating no corrosio	n

in the system.

#### Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The amount and size of particulates present in the system are acceptable.


#### **Fuel Condition**

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

R) ( GAL)			1	May2024		
SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06185695		
Sample Date		Client Info		08 May 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500		L4.0		
Visc @ 40°C	cSt	ASTM D445	3.0	2.42		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	59.1		
SULFUR CONTE	NΤ	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0		
Sulfur (UVF)	ppm	ASTM D5453		9		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	170		
5% Distillation Point	°C	ASTM D86		191		
10% Distill Point	°C	ASTM D86	201	200		
15% Distillation Point	°C	ASTM D86		208		
20% Distill Point	°C	ASTM D86	216	216		
30% Distill Point	°C	ASTM D86	230	230		
40% Distill Point	°C	ASTM D86	243	243		
50% Distill Point	°C	ASTM D86	255	257		
60% Distill Point	°C	ASTM D86	267	271		
70% Distill Point	°C	ASTM D86	280	286		
80% Distill Point	°C	ASTM D86	295	302		
85% Distillation Point	°C	ASTM D86		313		
90% Distill Point	°C	ASTM D86	310	324		
95% Distillation Point	°C	ASTM D86		343		
Final Boiling Point	°C	ASTM D86	341	358		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	37		
Cetane Index		ASTM D4737	<40.0	48		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1		
Sodium	ppm	ASTM D5185m	< 0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.002		
ppm Water	ppm	ASTM D6304	<500	21		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



### **FUEL REPORT**







Certificate 12367

Sample No.

Lab Number : 06185695

: WC06185695 Unique Number : 11037021

Received : 20 May 2024 **Tested** Diagnosed

: 28 May 2024

: 28 May 2024 - Angela Borella Test Package : DF-2 (Additional Tests: Fuel, Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: AJAY EL - PETSUM

210 POWELL DR

Contact: AJAY EL

Ajay@prsfuel.com

T: (843)225-1777

US 29483

SUMMERVILLE, SC