

NORMAL

Area **Colleton Medical Center** [Colleton Medical Center] GEN 1

Diesel Fuel

Fluid No.2 DIESEL FUEL (ULTRALOW SULPHUR) (3000 GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.






SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06185734		
Sample Date		Client Info		20 May 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	3.0	2.59		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	60		
SULFUR CONTER	١T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0		
Sulfur (UVF)	ppm	ASTM D5453		13		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	170		
5% Distillation Point	°C	ASTM D86		194		
10% Distill Point	°C	ASTM D86	201	204		
15% Distillation Point	°C	ASTM D86		212		
20% Distill Point	°C	ASTM D86	216	221		
30% Distill Point	°C	ASTM D86	230	236		
40% Distill Point	°C	ASTM D86	243	250		
50% Distill Point	°C	ASTM D86	255	264		
60% Distill Point	°C	ASTM D86	267	278		
70% Distill Point	°C	ASTM D86	280	292		
80% Distill Point	°C	ASTM D86	295	307		
85% Distillation Point	°C	ASTM D86		318		
90% Distill Point	°C	ASTM D86	310	328		
95% Distillation Point	°C	ASTM D86		346		
Final Boiling Point	°C	ASTM D86	341	362		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36		
Cetane Index		ASTM D4737	<40.0	48		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.002		
ppm Water	ppm	ASTM D6304	<500	21		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		





FUEL REPORT



FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	85		
Particles >6µm		ASTM D7647	>640	28		
Particles >14µm		ASTM D7647	>80	3		
Particles >21µm		ASTM D7647	>20	1		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	14/12/9		
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0		
Nickel	ppm	ASTM D5185m	<0.1	0		
Lead	ppm	ASTM D5185m	<0.1	0		
Vanadium	ppm	ASTM D5185m	<0.1	0		
ron	ppm	ASTM D5185m	<0.1	0		
Calcium	ppm	ASTM D5185m	<0.1	0		
Vagnesium	ppm	ASTM D5185m	<0.1	0		
Phosphorus	ppm	ASTM D5185m	<0.1	<1		
Zinc	ppm	ASTM D5185m	<0.1	0		
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image
				The second		


Bottom





no image

no image



PETROLEUM RECOVERY SERVICES : WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC06185734 210 POWELL DR Received : 20 May 2024 Lab Number : 06185734 Tested : 28 May 2024 SUMMERVILLE, SC Unique Number : 11037060 Diagnosed : 28 May 2024 - Doug Bogart US 29483 Test Package : DF-2 (Additional Tests: Fuel, Screen) Contact: AJAY EL Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. Ajay@prsfuel.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (843)225-1777 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: PETSUM [WUSCAR] 06185734 (Generated: 05/28/2024 20:01:05) Rev: 1

Contact/Location: AJAY EL - PETSUM

Page 2 of 2

E: