

COOLANT REPORT



Machine Id **1629** Component **Coolant** Fluid **{not provided} (--- GAL)**

DIAGNOSIS

A Recommendation

We recommend that you perform a partial drain and top off with straight water to decrease abnormal level of overconcentrated antifreeze.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition


The glycol level is higher than acceptable. The nitrite level is acceptable. The pH level of this fluid is within the acceptable limits.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0757398		
Sample Date		Client Info		01 May 2024		
Machine Age	hrs	Client Info		589		
Oil Age	hrs	Client Info		589		
Oil Changed		Client Info		Not Changd		
Sample Status				ABNORMAL		
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.096		
рН	Scale 0-14	ASTM D1287		8.41		
Nitrites	ppm	AP-053:2009		1616		
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		<u> </u>		
Freezing Point	°F	ASTM D3321		<u> </u>		
Total Dissolved Solids				431.5		
Carboxylate				n/a		
VISUAL		method	limit/base	current	history1	history2
		*) // 1		- .		

Coolant Color	*Visual		Red		
Coolant Appearance	*Visual	Clear	normal		
Color				no image	no image
Bottom				no image	no image



COOLANT REPORT







Unique Number : 11037076 Diagnosed : 24 May 2024 - Jonathan Hester Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. BHood@neogenservice.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: HSSBEA [WUSCAR] 06185750 (Generated: 05/24/2024 15:59:26) Rev: 1

Contact/Location: BILL HOOD - HSSBEA

F:

Contact: BILL HOOD

T: (330)284-8390