




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
OKLAHOMA CITY
 Machine Id
2018 FREIGHTLINER 7729
 Component
Diesel Engine
 Fluid
SHELL Rotella T5 15W-40 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0559214	WC0559210	WC0559207
Sample Date	Client Info		09 May 2024	05 Apr 2024	02 Mar 2024
Machine Age	hrs	Client Info	3949	3996	3695
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>3.0	<1.0	<1.0	<1.0
Water	WC Method	>0.2	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>65	37	32	31
Chromium	ppm	ASTM D5185m	>5	5	5	5
Nickel	ppm	ASTM D5185m	>3	1	0	1
Titanium	ppm	ASTM D5185m	>5	0	0	<1
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>35	19	15	15
Lead	ppm	ASTM D5185m	>10	<1	<1	2
Copper	ppm	ASTM D5185m	>180	37	35	31
Tin	ppm	ASTM D5185m	>8	4	3	6
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	2

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		55	54	41
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		85	79	72
Manganese	ppm	ASTM D5185m		1	<1	2
Magnesium	ppm	ASTM D5185m		260	231	251
Calcium	ppm	ASTM D5185m		2171	2157	2207
Phosphorus	ppm	ASTM D5185m		1100	1042	1143
Zinc	ppm	ASTM D5185m		1428	1344	1444
Sulfur	ppm	ASTM D5185m		3757	3665	3969

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>15	6	5	5
Sodium	ppm	ASTM D5185m		4	2	3
Potassium	ppm	ASTM D5185m	>20	34	24	26

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844	>3	0.8	0.7	0.7
Nitration	Abs/cm	*ASTM D7624	>20	10.6	10.1	9.8
Sulfation	Abs/.1mm	*ASTM D7415	>30	24.8	23.2	22.7


FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	19.8	18.1	17.9
Base Number (BN)	mg KOH/g	ASTM D2896	10	4.4	5.3	3.1




OIL ANALYSIS REPORT


FT-IR (Direct Trend)



Base Number











Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.9	14.0	14.1

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0559214 **Received** : 28 May 2024
Lab Number : 06193376 **Tested** : 30 May 2024
Unique Number : 11050128 **Diagnosed** : 30 May 2024 - Sean Felton
Test Package : MOB1+

LIBERTY DISPOSAL
 6401 S EASTERN AVE
 OKLAHOMA CITY, OK
 US 73149
 Contact: RICK SCHMIDT
 r.schmidt@ldi89.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)