

## **FUEL REPORT**



Machine Id

## FIRE PUMP

Diesel Fuel Fluid DIESEL FUEL No. 2 (--- GAL)

### DIAGNOSIS

#### A Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system.

#### Corrosion

All metal levels are normal indicating no corrosion in the system.

## Contaminants

There is a high amount of particulates present in the fuel. There is a moderate concentration of Bacteria, Yeast and/or Fungus present in the sample. Moderate concentration of visible dirt/debris present in the fuel.


### **Fuel Condition**


Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0013454		
Sample Date		Client Info		08 May 2024		
Machine Age	hrs	Client Info		0		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	4.1	2.68		
Pensky-Martens Flash Point	°C	*PMCC Calculated		73.2		
SULFUR CONTEN	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		23		
Sulfur (UVF)	ppm	ASTM D5453		8		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		185		
5% Distillation Point	°C	ASTM D86		208		
10% Distill Point	°C	ASTM D86		216		
15% Distillation Point	°C	ASTM D86		223		
20% Distill Point	°C	ASTM D86		230		
30% Distill Point	°C	ASTM D86		243		
40% Distill Point	°C	ASTM D86		254		
50% Distill Point	°C	ASTM D86		266		
60% Distill Point	°C	ASTM D86		278		
70% Distill Point	°C	ASTM D86		290		
80% Distill Point	°C	ASTM D86		303		
85% Distillation Point	°C	ASTM D86		313		
90% Distill Point	°C	ASTM D86		322		
95% Distillation Point	°C	ASTM D86		338		
Final Boiling Point	°C	ASTM D86		352		
IGNITION QUALI	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		33		
Cetane Index		ASTM D4737	<40.0	44		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	2		
Potassium	ppm	ASTM D5185m	<0.1	2		
Water	%	ASTM D6304	< 0.05	0.008		
ppm Water	ppm	ASTM D6304	<500	86		
% Gasoline	%	*In-House	<0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		




# **FUEL REPORT**







FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	A 72623		
Particles >6µm		ASTM D7647	>640	A 26898		
Particles >14µm		ASTM D7647	>80	<b>2088</b>		
Particles >21µm		ASTM D7647	>20	<b>467</b>		
Particles >38µm		ASTM D7647	>4	<b>1</b> 6		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	<b>4</b> 23/22/18		
MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	WC-Method	>=100000	0		
Yeast	CFU/ml	WC-Method	>=100000	<u> </u>		
Mold	Colonies	WC-Method	MODER			
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0		
Nickel	ppm	ASTM D5185m	<0.1	<1		
Lead	ppm	ASTM D5185m	<0.1	<1		
Vanadium	ppm	ASTM D5185m	<0.1	0		
Iron	ppm	ASTM D5185m	<0.1	0		
Calcium	ppm	ASTM D5185m	<0.1	<1		
Magnesium	ppm	ASTM D5185m	<0.1	<1		
Phosphorus	ppm	ASTM D5185m	<0.1	0		
Zinc	ppm	ASTM D5185m	<0.1	0		
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image



Contact/Location: Service Manager - FLIMEN Page 2 of 2