

## **OIL ANALYSIS REPORT**



Machine Id **PLATA SILAO** Component Heat Transfer Fluid Fluid {not provided} (--- LTR)

## DIAGNOSIS

## A Recommendation

The fluid is suitable for further service. Resample at the next service interval to monitor. All tests and evaluation performed at WearCheck Canada.

Fluid Condition

Visc @ 40°C is abnormally low.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		TO10003417			
Sample Date		Client Info		27 May 2024			
Machine Age	hrs	Client Info		0			
Oil Age	hrs	Client Info		0			
Oil Changed		Client Info		N/A			
Sample Status				ABNORMAL			
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	9			
Chromium	ppm	ASTM D5185m	>21	0			
Nickel	ppm	ASTM D5185m	>21	0			
Titanium	ppm	ASTM D5185m	>21	0			
Silver	ppm	ASTM D5185m	>21	0			
Aluminum	ppm	ASTM D5185m	>21	0			
Lead	ppm	ASTM D5185m	>21	1			
Copper	ppm	ASTM D5185m	>21	0			
Tin	ppm	ASTM D5185m	>21	0			
Antimony	ppm	ASTM D5185m	>21	0			
Vanadium	ppm	ASTM D5185m		0			
Beryllium	ppm	ASTM D5185m		0			
Cadmium	ppm	ASTM D5185m		0			
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0			
Barium	ppm	ASTM D5185m		10			
Molybdenum	ppm	ASTM D5185m		0			
Manganese	ppm	ASTM D5185m		0			
Magnesium	ppm	ASTM D5185m		<1			
Calcium	ppm	ASTM D5185m		<1			
Phosphorus	ppm	ASTM D5185m		1			
Zinc	ppm	ASTM D5185m		<1			
Sulfur	ppm	ASTM D5185m		4573			
Lithium	ppm	ASTM D5185m		<1			
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>25	0			
Sodium	ppm	ASTM D5185m		<1			
Potassium	ppm	ASTM D5185m		0			
Water	%	ASTM D6304	>0.0601	0.003			
ppm Water	ppm	ASTM D6304	>601	35			
FLUID DEGRADA	TION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.26			
FLUID PROPERT	IES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445		<b>43.4</b>			
COC Flash Point	°C	ASTM D92		220			
SEDIMENT		method	limit/base	current	history1	history2	
Pentane Insolubles	%	*ASTM D893		0.142			
9:29:30) Rev: 1	Contact/Location: ADRIAN BUATISTA - ERGSIL						

ontact/Location: ADRIAN BUATISTA SIL Page 1 of 2



CURN I

1200

100 Se

80 600

200

1.40 Severe

1.20 (B/HOX 1.00

Ê 0.80

e 0.60

Arid 1

0.40

0.20 0.00

20

15

cSt (100°C)

4 CI L CINEM

Mav27/24

Abnorma


0

ACITCIMA

Water 40 Water (KF)

## **OIL ANALYSIS REPORT**






SIMULATED DISTILLAT	ON (GCD)	method	limit/base	current	history1	history2
(GCD) % < 335°C	°C	*ASTM D2887		6.21		
(GCD) Initial Boiling Point	°C	*ASTM D2887	122	98.4		
(GCD) 5% Distillation Point	°C	*ASTM D2887		325.4		
(GCD) 10% Distillation Point	°C	*ASTM D2887	157	350.2		
(GCD) 20% Distillation Point	°C	*ASTM D2887		384.4		
(GCD) 30% Distillation Point	°C	*ASTM D2887		409.2		
(GCD) 40% Distillation Point	°C	*ASTM D2887		428.7		
(GCD) 50% Distillation Point	°C	*ASTM D2887	204	444.9		
(GCD) 60% Distillation Point	°C	*ASTM D2887		459.6		
(GCD) 70% Distillation Point	°C	*ASTM D2887		474.8		
(GCD) 80% Distillation Point	°C	*ASTM D2887		492.3		
(GCD) 90% Distillation Point	°C	*ASTM D2887		517.0		
(GCD) FBP% Distillation Point	°C	*ASTM D2887	322	578.6		



GRAPHS

ACITCUEA





Contact/Location: ADRIAN BUATISTA - ERGSIL