


OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Machine Id
TUXPAN
Component
Heat Transfer Fluid
Fluid
{not provided} (--- LTR)

DIAGNOSIS

Recommendation

The fluid is suitable for further service. Resample at the next service interval to monitor. All tests and evaluation performed at WearCheck Canada.

Fluid Condition

Visc @ 40°C is abnormally low.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			TO106913493	---	---
Sample Date	Client Info			27 May 2024	---	---
Machine Age	hrs	Client Info		0	---	---
Oil Age	hrs	Client Info		0	---	---
Oil Changed	Client Info			N/A	---	---
Sample Status				ABNORMAL	---	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	13	---	---
Chromium	ppm	ASTM D5185m	>21	0	---	---
Nickel	ppm	ASTM D5185m	>21	0	---	---
Titanium	ppm	ASTM D5185m	>21	0	---	---
Silver	ppm	ASTM D5185m	>21	0	---	---
Aluminum	ppm	ASTM D5185m	>21	0	---	---
Lead	ppm	ASTM D5185m	>21	0	---	---
Copper	ppm	ASTM D5185m	>21	0	---	---
Tin	ppm	ASTM D5185m	>21	<1	---	---
Antimony	ppm	ASTM D5185m	>21	0	---	---
Vanadium	ppm	ASTM D5185m		0	---	---
Beryllium	ppm	ASTM D5185m		0	---	---
Cadmium	ppm	ASTM D5185m		0	---	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	---	---
Barium	ppm	ASTM D5185m		0	---	---
Molybdenum	ppm	ASTM D5185m		0	---	---
Manganese	ppm	ASTM D5185m		0	---	---
Magnesium	ppm	ASTM D5185m		<1	---	---
Calcium	ppm	ASTM D5185m		1	---	---
Phosphorus	ppm	ASTM D5185m		5	---	---
Zinc	ppm	ASTM D5185m		<1	---	---
Sulfur	ppm	ASTM D5185m		3791	---	---
Lithium	ppm	ASTM D5185m		<1	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	---	---
Sodium	ppm	ASTM D5185m	>21	0	---	---
Potassium	ppm	ASTM D5185m	>20	<1	---	---
Water	%	ASTM D6304	>0.0601	0.001	---	---
ppm Water	ppm	ASTM D6304	>601	8	---	---


FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.22	---	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		▲ 45.4	---	---
COC Flash Point	°C	ASTM D92		228	---	---


SEDIMENT		method	limit/base	current	history1	history2
Pentane Insolubles	%	*ASTM D893		0.087	---	---

OIL ANALYSIS REPORT

Gas Chromatography (GCD)




Flash Point (°C)




Water (KF)



Acid Number



Viscosity @ 100°C




SIMULATED DISTILLATION (GCD)	method	limit/base	current	history1	history2
(GCD) % < 335°C	°C	*ASTM D2887	3.69	---	---
(GCD) Initial Boiling Point	°C	*ASTM D2887	98.0	---	---
(GCD) 5% Distillation Point	°C	*ASTM D2887	342.0	---	---
(GCD) 10% Distillation Point	°C	*ASTM D2887	367.5	---	---
(GCD) 20% Distillation Point	°C	*ASTM D2887	396.1	---	---
(GCD) 30% Distillation Point	°C	*ASTM D2887	415.6	---	---
(GCD) 40% Distillation Point	°C	*ASTM D2887	430.9	---	---
(GCD) 50% Distillation Point	°C	*ASTM D2887	444.4	---	---
(GCD) 60% Distillation Point	°C	*ASTM D2887	456.7	---	---
(GCD) 70% Distillation Point	°C	*ASTM D2887	469.5	---	---
(GCD) 80% Distillation Point	°C	*ASTM D2887	484.7	---	---
(GCD) 90% Distillation Point	°C	*ASTM D2887	507.7	---	---
(GCD) FB% Distillation Point	°C	*ASTM D2887	575.5	---	---


SAMPLE IMAGES	method	limit/base	current	history1	history2
Color			no image	no image	no image
Bottom			no image	no image	no image

GRAPHS

Gas Chromatography Distillation (GCD)



Viscosity @ 40°C



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO106913493
Lab Number : 06193493
Unique Number : 11050245
Test Package : IND 2 (Additional Tests: COC Flash, GCD, KF, KV100, PntInsol, VI)

Received : 28 May 2024
Tested : 17 Jun 2024
Diagnosed : 17 Jun 2024 - Doug Bogart

ERGON - TUXPAN
 LOTE 1 MANZANA 3, PARK INDUSTRIAL, LITORAL DEL GOLFO
 TUXPAN, ZZ
 MX 92770
 Contact: NAPOLEON CRUZ
 napoleon.cruz@ergon.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: