


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER BSV 100 4717112 (S/N 1013)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Check seals and/or filters for points of contaminant entry. We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Dec2016	May2024		
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012390	KCP61451	
Sample Date		Client Info		03 May 2024	20 Dec 2016	
Machine Age	hrs	Client Info		45519	136354	
Oil Age	hrs	Client Info		3639	6518	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	3	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	<1	<1	
Copper	ppm	ASTM D5185m	>50	2	3	
Tin	ppm	ASTM D5185m	>10	<1	1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	
Barium	ppm	ASTM D5185m	90	92	109	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	89	113	
Calcium	ppm	ASTM D5185m	2	3	3	
Phosphorus	ppm	ASTM D5185m		15	0	
Zinc	ppm	ASTM D5185m		3	2	
Sulfur	ppm	ASTM D5185m		19790	8537	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	102	<u></u> 51	
Sodium	ppm	ASTM D5185m		13	12	
Potassium	ppm	ASTM D5185m	>20	3	1	
Water	%	ASTM D6304	>0.05	0.031	0.026	
ppm Water	ppm	ASTM D6304	>500	311	260	
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6829	5696	
Particles >6µm		ASTM D7647	>1300	<u> </u>	1619	
Particles >14µm		ASTM D7647	>80	186	<u>▲</u> 182	
Particles >21µm		ASTM D7647	>20	49	<u>46</u>	
Particles >38µm		ASTM D7647	>4	2	3	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/15	<u>▲</u> 18/15	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Laboratory Sample No.

Lab Number

: KCPA012390 : 06193978 Unique Number : 11056101

Received **Tested** Diagnosed

: 29 May 2024 : 30 May 2024

: 31 May 2024 - Angela Borella

705 CALLE PLANO CAMARILLO, CA US 93012 Contact:

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: HITCAM [WUSCAR] 06193978 (Generated: 05/31/2024 09:59:46) Rev: 1

Contact/Location: ? ? - HITCAM

T:

F: