


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# KAESER SM10T 5022905 (S/N 3579)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Nov2014	Feb2016 May2017	May2018 Jun2019 De	2020	
SAMPLE INFORM	//ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA010404	KC85161	KCP25333
Sample Date		Client Info		23 Jan 2024	17 Dec 2020	27 May 2020
Machine Age	hrs	Client Info		43666	27764	25234
Oil Age	hrs	Client Info		0	2530	4094
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	<1
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	<1	0
Copper	ppm	ASTM D5185m	>50	6	12	8
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Antimony	ppm	ASTM D5185m			0	8
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	8	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	<1	25	2
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	1	3	4
Zinc	ppm	ASTM D5185m	0	0	5	2
Sulfur	ppm	ASTM D5185m	23500	17778	16192	15597
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		<1	8	<1
Potassium	ppm	ASTM D5185m	>20	2	<1	4
Water	%	ASTM D6304	>0.05	0.005	0.008	0.006
ppm Water	ppm	ASTM D6304	>500	53	85.5	66.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1129	47261	18051
Particles >6µm		ASTM D7647	>1300	444	<u>▲</u> 10615	▲ 5033
Particles >14µm		ASTM D7647	>80	65	<b>▲</b> 884	▲ 396
Particles >21µm		ASTM D7647	>20	33	<u>^</u> 245	<b>△</b> 96
Particles >38µm		ASTM D7647	>4	8	<u> 11</u>	<u>^</u> 21
Particles >71µm		ASTM D7647	>3	1	0	<b>1</b> 6
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/13	<u>^</u> 21/17	<b>△</b> 20/16
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2





Water (KF)

12000

600

## OIL ANALYSIS REPORT





cSt 45.0 45.9 Visc @ 40°C ASTM D445 45 44.1

SAMPLE IMAGES


Color



















Laboratory Sample No. Lab Number

: KCPA010404 : 06193983

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 29 May 2024 **Tested** 

Diagnosed

: 30 May 2024 : 31 May 2024 - Angela Borella

NANOPRECISION PRODUCTS - CUDOFORM INC 802 CALLE PLANO CAMARILLO, CA

> US 93012-8557 Contact: SERVICE MANAGER

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

Unique Number : 11056106

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: Contact/Location: SERVICE MANAGER ? - NANCAMCA

T: