


OIL ANALYSIS REPORT



Machine Id

KAESER CSD 75 1854029 (S/N 1038)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC130856	KC84858	KC006335
Sample Date		Client Info		21 May 2024	09 Mar 2020	20 Feb 2007
Machine Age	hrs	Client Info		58279	43384	14633
Oil Age	hrs	Client Info		6000	4764	3205
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	<1
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		<1	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	1	<1
Lead	ppm	ASTM D5185m	>25	<1	0	1
Copper	ppm	ASTM D5185m	>50	4	15	12
Tin	ppm	ASTM D5185m	>15	<1	0	0
Antimony	ppm	ASTM D5185m			0	9
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	1
Barium	ppm	ASTM D5185m	90	44	<1	8
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	90	61	16	40
Calcium	ppm	ASTM D5185m	2	2	<1	0
Phosphorus	ppm	ASTM D5185m		1	1	14
Zinc	ppm	ASTM D5185m		11	12	31
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon		ASTM D5185m	>25	<1	<1	3
Sodium	ppm	ASTM D5185m	>20	26	10	51
Potassium	ppm	ASTM D5185m	>20	6	10	5
	ppm %			0.022	0.008	0.009
Water ppm Water	ppm	ASTM D6304 ASTM D6304	>0.1	227	86.4	0.009
FLUID CLEANLIN		method	limit/base	current	history1	history2
	ESS		IIIIIIIIIIIIIII			
Particles >4µm		ASTM D7647	0.500	76907	8197	29289
Particles >6µm		ASTM D7647		▲ 30425	2254	10833
Particles >14µm		ASTM D7647	>320	<u>A</u> 2252	111	▲ 1158
Particles >21µm		ASTM D7647		<u> 483</u>	22	<u>▲</u> 277
Particles >38µm		ASTM D7647	>20	15	3	<u>^</u> 27
Particles >71μm		ASTM D7647		1	1	<u>1</u>
Oil Cleanliness		ISO 4406 (c)	>18/15	<u>22/18</u>	18/14	<u>^</u> 21/17
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.36	0.367	0.587



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No. : KC130856 Lab Number : 06193988 Unique Number : 11056111 Test Package : IND 2

Received : 29 May 2024 **Tested** : 30 May 2024

Diagnosed : 31 May 2024 - Angela Borella

BRADFORD, PA US 16701 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F:

1 OWENS WAY