


## **OIL ANALYSIS REPORT**







# Machine Id MLU-1 Component Outboard Pump

## **ROYAL PURPLE SYNFILM GT 32 (--- GAL)**

DIAGNOSIS
-----------

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

The water content is negligible. There is no indication of any contamination in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Nov2023	May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0040229	RP0032092	
Sample Date		Client Info		23 May 2024	01 Nov 2023	
Machine Age	hrs	Client Info		0	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	5	4	
Chromium	ppm	ASTM D5185m	>5	<1	0	
Nickel	ppm	ASTM D5185m	>5	<1	<1	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>3	1	0	
Aluminum	ppm	ASTM D5185m	>7	1	<1	
Lead	ppm	ASTM D5185m	>12	2	1	
Copper	ppm	ASTM D5185m	>30	8	7	
Tin	ppm	ASTM D5185m	>9	1	1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m		69	84	
Calcium	ppm	ASTM D5185m		0	4	
Phosphorus	ppm	ASTM D5185m		5	4	
Zinc	ppm	ASTM D5185m		2	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	31	35	
Sodium	ppm	ASTM D5185m		8	12	
Potassium	ppm	ASTM D5185m	>20	1	1	
Water	%	ASTM D6304	>.1	0.021	0.025	
ppm Water	ppm	ASTM D6304	>1000	220	254	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.33	0.34	
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	LIGHT	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>.1	NEG	NEG	
Free Water	scalar	*Visual		NEG	Submitted By: S	Bage 1 of 2



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory

**Sample No.** : RP0040229 Lab Number : 06194086 Unique Number : 11056209

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 29 May 2024

**Tested** : 30 May 2024

Diagnosed : 31 May 2024 - Angela Borella

**ENERGY TRANSFER - KARNACK** 11398 SH-43

KARNACK, TX US 75661

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: