

# **OIL ANALYSIS REPORT**

# Sample Rating Trend

# **NORMAL**



CTL64.1

# CTL 64.1 Uncoiler - MAIN (S/N 16-5220-0115)

Component Gearbox

ISO 220 (--- QTS)

#### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The water content is negligible. There is no indication of any contamination in the oil.

## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		ul2015 Jur	.2016 May2017 May2	018 Jan2020 Jun2021 J	an2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0044278	RP0034946	RP0030866
Sample Date		Client Info		28 May 2024	24 Jul 2023	18 Jan 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		25	21	64
Iron	ppm	ASTM D5185m	>200	21	19	28
Chromium	ppm	ASTM D5185m	>15	<1	0	0
Nickel	ppm	ASTM D5185m	>15	<1	0	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		1	0	0
Aluminum	ppm	ASTM D5185m	>25	1	<1	0
Lead	ppm	ASTM D5185m	>100	<1	0	<1
Copper	ppm	ASTM D5185m	>200	5	4	4
Tin	ppm	ASTM D5185m	>25	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		<1	0	0
Calcium	ppm	ASTM D5185m		11	20	21
Phosphorus	ppm	ASTM D5185m		94	102	110
Zinc	ppm	ASTM D5185m		5	0	5
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	7	5	6
Sodium	ppm	ASTM D5185m		<1	1	0
Potassium	ppm	ASTM D5185m	>20	1	0	1
Water	%	ASTM D6304	>0.2	0.003	0.003	0.011
ppm Water	ppm	ASTM D6304	>2000	33	37.1	116.3
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.26

0.21


Acid Number (AN)

mg KOH/g ASTM D8045


0.26




# **OIL ANALYSIS REPORT**



12000 -	Water (KF	)					
10000 -	Severe	-	-		-		
€ 8000							
Water (ppm)							
≥ 4000.							
2000 -	Abnormal	++++	+++	+++	+++		-
0 -	9		- 60	0.0	21	83	_
	Jul13/15 Jun3/16	May19/	May22/18	Jan 16/20	Jun8/21	Jan18/23	





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
ELLIN DRODERT		mothod	limit/basa	current	history1	history?

LLOID PHOPE	711EO	method			riistory i	HISTORY
Visc @ 40°C	cSt	ASTM D445	220	226	227	226

SAM	PLE	<b>IMAGES</b>	

**Bottom** 


Color
























Certificate 12367

Laboratory Sample No.

Lab Number : 06194118

: RP0044278

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested** 

: 29 May 2024 : 30 May 2024 Diagnosed : 31 May 2024 - Angela Borella

Unique Number : 11056241 Test Package : IND 2 ( Additional Tests: PQ ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**OUTOKUMPU STAINLESS USA** 

HWY 43 N CALVERT, AL US 36513

Contact: MARIO JOHNSON Mario.johnson@outokumpu.com T: (251)321-4105

F: x: