


# **OIL ANALYSIS REPORT**

Area

# SYNOIL 8K FG LEROI W3055B 4215X214-KAYTEE PRODUCTS

Component Compressor





#### DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil.


## **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		UCZ06194189	UCZ06096357	UCZ05884577	
Sample Date		Client Info		15 May 2024	02 Feb 2024	16 Jun 2023	
Machine Age	hrs	Client Info		40042	38805	36232	
Oil Age	hrs	Client Info		4750	3147	574	
Oil Changed		Client Info		<b>N/A</b> N/A N/A		N/A	
Sample Status				NORMAL	NORMAL	NORMAL	
CONTAMINATION		method	limit/base	current	history1	history2	
Water		WC Method	>0.1	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>50	<1	<1	0	
Chromium	ppm	ASTM D5185m	>5	<1	<1	0	
Nickel	ppm	ASTM D5185m		<1	0	0	
Titanium	ppm	ASTM D5185m		<1	<1	0	
Silver	ppm	ASTM D5185m		1	<1	0	
Aluminum	ppm	ASTM D5185m	>15	1	2	0	
Lead	ppm	ASTM D5185m	>65	1	0	<1	
Copper	ppm	ASTM D5185m	>65	6	7	10	
Tin	ppm	ASTM D5185m	>10	<1	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	0	
Cadmium	ppm	ASTM D5185m		<1	0	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	1	0	0	0	
Barium	ppm	ASTM D5185m	0.3	0	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	0	0	
Manganese	ppm	ASTM D5185m	0	<1	0	0	
Magnesium	ppm	ASTM D5185m	0	<1	0	0	
Calcium	ppm	ASTM D5185m	0.5	0	<1	0	
Phosphorus	ppm	ASTM D5185m	536	126	148	275	
Zinc	ppm	ASTM D5185m	0.2	2	0	10	
Sulfur	ppm	ASTM D5185m	649	360	457	1390	
CONTAMINANTS	;	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>35	1	0	<1	
Sodium	ppm	ASTM D5185m		0	0	0	
Potassium	ppm	ASTM D5185m	>20	1	1	<1	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.337	0.74	0.74	0.36	



# **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2

Visc @ 40°C	cSt	ASTM D445	42.0	44.6	44.5	42.1
_						


SAMPLE IMAGES


Color


**Bottom** 


















Certificate 12367

Laboratory

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. Lab Number : 06194189

Test Package : IND 2

: UCZ06194189 Unique Number : 11056312

Received : 29 May 2024 **Tested** : 30 May 2024 Diagnosed

: 30 May 2024 - Wes Davis

**ZORN COMP & EQUIPMENT CO (GB)** 733 POTTS AVE GREEN BAY, WI US 54304

Contact: DEAN SCHAD dean.schad@zornair.com T: (920)391-8121

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (920)499-1168