

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area NOT GIVEN Machine Id KAESER 1158 - REILLY FOAM CORP

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	/AT <u>ION</u>	method	limit/base	current	history1	history2
Sample Number		Client Info		UDI0000280		
Sample Date		Client Info		21 May 2024		
Machine Age	hrs	Client Info		14014		
Oil Age	hrs	Client Info		4000		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
·		_				
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	1		
Aluminum	ppm	ASTM D5185m	>10	1		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>50	8		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		5		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		0		
Zinc	ppm	ASTM D5185m		5		
Sulfur	ppm	ASTM D5185m		18357		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37		



OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
+	Sand/Dirt	scalar	*Visual	NONE	NONE		
May21/24	Appearance	scalar	*Visual	NORML	NORML		
Ψ.	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water Free Water	scalar	*Visual *Visual	>0.05	NEG		
		scalar			NEG		
	FLUID PROPER		method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		44.4		
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
May21/24	Color					no image	no image
	Bottom					no image	no image
	Ferrous Alloys			May21/24			
				Mayû			
	Viscosity @ 40°C			0.40	Acid Number		
	50 - Abnormal 50			0.40 300 (und KOHrd) 0.10 Vmmpe 0.10 Vmmpe			
	35 4 + +++++++++++++++++++++++++++++++++			May21/24	May21/24		AC LC M
Laboratory Sample No.	: WearCheck USA - 50 : UDI0000280 : 06194210	Rece	Madison Ave., Cary, NC 27513DELTAReceived: 29 May 2024Tested: 30 May 2024Diagnosed: 30 May 2024 - Wes Davisat 1-800-237-1369.25 scope of accreditation.			INDUSTRIES - DOWNERS GROV 2201 CURTISS STREE DOWNERS GROVE, I US 6051 Contact: MICHAEL FERRI T	

Contact/Location: MICHAEL FERRIS - UCDELDOW