FUEL REPORT

Sample Rating Trend



NORMAL

Area
[W156256]
Machine Id
IAD2-A-GEN-01 IAD2-A-GEN-01
Component
Diesel Fuel
Fluid
DIESEL FUEL No. 2 (--- GAL)

DIAGNOSIS

Recommendation
All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion
All metal levels are normal indicating no corrosion in the system.

Contaminants
The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.

Fuel Condition
Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0911292**	---	---
Sample Date		Client Info		**13 May 2024**	---	---
Machine Age	hrs	Client Info		**0**	---	---
Sample Status				**NORMAL**	---	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		**L4.0**	---	---
Visc @ 40°C	cSt	ASTM D445	4.1	**2.53**	---	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		**0**	---	---
Sulfur (UVF)	ppm	ASTM D5453		**9**	---	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	**<1**	---	---
Sodium	ppm	ASTM D5185m	<0.1	**2**	---	---
Potassium	ppm	ASTM D5185m	<0.1	**<1**	---	---
Water	%	ASTM D6304	<0.05	**0.002**	---	---
ppm Water	ppm	ASTM D6304	<500	**19**	---	---
% Gasoline	%	*In-House	<0.50	**0.0**	---	---
% Biodiesel	%	*In-House	<20.0	**0.0**	---	---

HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	**0**	---	---
Nickel	ppm	ASTM D5185m	<0.1	**0**	---	---
Lead	ppm	ASTM D5185m	<0.1	**<1**	---	---
Vanadium	ppm	ASTM D5185m	<0.1	**<1**	---	---
Iron	ppm	ASTM D5185m	<0.1	**0**	---	---
Calcium	ppm	ASTM D5185m	<0.1	**0**	---	---
Magnesium	ppm	ASTM D5185m	<0.1	**0**	---	---
Phosphorus	ppm	ASTM D5185m	<0.1	**<1**	---	---
Zinc	ppm	ASTM D5185m	<0.1	**0**	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				*no image*	*no image*
Bottom				*no image*	*no image*

FUEL REPORT

Water (KF)



Viscosity @ 40°C



GRAPHS

Pensky-Martens Flash Point (°C)



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0911292 **Received** : 29 May 2024
Lab Number : 06194536 **Tested** : 11 Jun 2024
Unique Number : 11056659 **Diagnosed** : 11 Jun 2024 - Doug Bogart
Test Package : DF-5 (Additional Tests: PrtCount, Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NATIONAL POWER CORP
4541 PRESLYN DR
RALEIGH, NC
US 27616
Contact: Brandon Daniels
Brandon.Daniels@natpow.com
T:
F: (919)790-9714