

FUEL REPORT

[W156272] **IAD2-B-GEN-08 IAD2-B-GEN-08**

Diesel Fuel

DIESEL FUEL No. 2 (--- GAL)

Sample Rating Trend **NORMAL**

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel.


Fuel Condition


Sulfur value derived by ASTM D5453 method for ULSD validation.


		·		May2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0911296		
Sample Date		Client Info		06 May 2024		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	4.1	2.46		
SULFUR CONTE	٧T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		90		
Sulfur (UVF)	ppm	ASTM D5453		140		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1		
Sodium	ppm	ASTM D5185m	< 0.1	2		
Potassium	ppm	ASTM D5185m	<0.1	<1		
Water	%	ASTM D6304	< 0.05	0.003		
ppm Water	ppm	ASTM D6304	< 500	29		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	< 0.1	0		
Nickel	ppm	ASTM D5185m	<0.1	0		
Lead	ppm	ASTM D5185m	< 0.1	<1		
Vanadium	ppm	ASTM D5185m	<0.1	<1		
Iron	ppm	ASTM D5185m	<0.1	0		
Calcium	ppm	ASTM D5185m	< 0.1	0		
Magnesium	ppm	ASTM D5185m	<0.1	<1		
Phosphorus	ppm	ASTM D5185m	<0.1	<1		
Zinc	ppm	ASTM D5185m	<0.1	0		
SAMPLE IMAGES	;	method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image



FUEL REPORT









Certificate 12367

Laboratory

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : WC0911296 Lab Number : 06194537

Unique Number : 11056660

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received Tested

: 29 May 2024 Diagnosed Test Package: DF-5 (Additional Tests: PrtCount, Screen)

: 12 Jun 2024 : 12 Jun 2024 - Doug Bogart

4541 PRESLYN DR RALEIGH, NC US 27616

NATIONAL POWER CORP

Contact: Brandon Daniels Brandon.Daniels@natpow.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (919)790-9714 Contact/Location: Brandon Daniels - NATRAL